

COOLANT REPORT

Sample Rating Trend

NORMAL

Area [W156280] IAD3-A-GEN-04 IAD3-A-GEN-04

Component Coolant

Fluid {not provided} (--- GAL)

DIAGNOSIS

Recommendation The fluid is suitable for further service.

-

Contaminants There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.






SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0931786		
Sample Date		Client Info		09 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.067		
рН	Scale 0-14	ASTM D1287		8.41		
Nitrites	ppm	AP-053:2009		676		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.2		
Freezing Point	°F	ASTM D3321		-33		
Total Dissolved Solids				397.0		
Carboxylate				n/a		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Red		
Coolant Appearance		*Visual	Clear	normal		
Color					no image	no image
Bottom					no image	no image



COOLANT REPORT



Iron/Tin/Silver Reserve Alkalinity 14 12 e tin 13 10 q 10 Reserve Alkalinity Mav9/24 Copper/Aluminum/Lead Freeze Point 10 10 -5 -10 mdo 8-20 -25 -30 -35 -40 -45 Mav9/24 Mav9/74 Am/9/74 Nitrites pН 14 3000 Abr 13 2800 12 2600 2400 10 2200 2000 ន្ល 1800 핍 1600 1400 1200 1000 800 600 400 Mav9/24 Mav9/74 NATIONAL POWER CORP Received 4541 PRESLYN DR : 29 May 2024



Contact/Location: Brandon Daniels - NATRAL Page 2 of 2