

OIL ANALYSIS REPORT

Sample Rating Trend **VIS DEBRIS**

Machine Id

KAESER AS 20 7502970 (S/N 1277)

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012995	KCPA010346	KCP55903
Sample Date		Client Info		20 May 2024	28 Nov 2023	14 Feb 2023
Machine Age	hrs	Client Info		14360	12269	8907
Oil Age	hrs	Client Info		2400	0	8907
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	0	0
Chromium	ppm	ASTM D5185m	>10	1	<1	0
Nickel	ppm	ASTM D5185m	>3	1	0	0
Titanium	ppm	ASTM D5185m	>3	1	0	0
Silver	ppm	ASTM D5185m	>2	2	0	0
Aluminum	ppm	ASTM D5185m	>10	1	2	0
Lead	ppm	ASTM D5185m	>10	1	0	0
Copper	ppm	ASTM D5185m	>50	18	23	16
Tin	ppm	ASTM D5185m	>10	1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	3
Molybdenum	ppm	ASTM D5185m		1	0	0
Manganese	ppm	ASTM D5185m		2	0	0
Magnesium	ppm	ASTM D5185m	90	21	11	<1
Calcium	ppm	ASTM D5185m	2	0	<1	<1
Phosphorus	ppm	ASTM D5185m		0	41	0
Zinc	ppm	ASTM D5185m		3	5	6
Sulfur	ppm	ASTM D5185m		21005	21366	17679
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	0	0
Sodium	ppm	ASTM D5185m		8	<1	<1
Potassium	ppm	ASTM D5185m	>20	4	2	0
Water	%	ASTM D6304	>0.05	0.022	0 .119	0.007
ppm Water	ppm	ASTM D6304	>500	225	1 190	78.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647				17578
Particles >6µm		ASTM D7647	>1300			▲ 7442
Particles >14µm		ASTM D7647	>80			2 06
Particles >21µm		ASTM D7647	>20			<mark>▲</mark> 32
Particles >38µm		ASTM D7647	>4			2
Particles >71µm		ASTM D7647	>3			0
Oil Cleanliness		ISO 4406 (c)	>/17/13			▲ 21/20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.31	0.30



OIL ANALYSIS REPORT

	12000 -	Water (KF)			
	10000.	Severe				
(E	8000.					
Water (ppm)	6000-					
Wa	4000.					
	2000•	Abnormal				
	0-	Abnormal	2			4
		Dec10/2	Jul18/22	Feb14/23	Nov28/23	May20/24
	12000 -	Water (KF)			2
	10000•	Severe				
(L	8000-					
Water (ppm)	6000-					
Wate	4000.					
	2000•					
	0-	Abnormal				-



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	A MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	44.1	44.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2

Color



Bottom

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



Report Id: ELIMOS [WUSCAR] 06194619 (Generated: 05/31/2024 19:52:01) Rev: 1

Certificate 12367

Contact/Location: A. MILLER - ELIMOS

T:

F: