


OIL ANALYSIS REPORT



Machine Id

4366727 (S/N 1102)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

A Wear

The copper level is abnormal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition


The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirm oil type.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013753	KCP49586	
Sample Date		Client Info		25 Mar 2024	19 Jul 2022	
Machine Age	hrs	Client Info		29848	25638	
Oil Age	hrs	Client Info		0	9597	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	1	<1	
Aluminum	ppm	ASTM D5185m	>10	3	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m		<u> </u>	37	
Tin	ppm	ASTM D5185m	>10	1	0	
Vanadium	ppm	ASTM D5185m	210	، <1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	00	ء <1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	3	<1	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus		ASTM D5185m	2	5 71	2	
Zinc	ppm	ASTM D5185m		172	0	
Sulfur	ppm			-	÷	
	ppm	ASTM D5185m		5245	17519	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		3	<1	
Potassium	ppm	AOTH DEADE				
	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D6304	>0.05	0.067	0.004	
Water ppm Water			>0.05			
	% ppm	ASTM D6304	>0.05	0.067	0.004	 history2
ppm Water FLUID CLEANLIN Particles >4µm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647	>0.05 >500 limit/base	 0.067 673 current 32965 	0.004 44.9	
ppm Water FLUID CLEANLIN	% ppm	ASTM D6304 ASTM D6304 method	>0.05 >500 limit/base	 0.067 673 current 	0.004 44.9 history1	 history2
ppm Water FLUID CLEANLIN Particles >4µm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647	>0.05 >500 limit/base	 0.067 673 current 32965 	0.004 44.9 history1 17289	 history2
ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647	>0.05 >500 limit/base >1300	 ▲ 0.067 ▲ 673 current 32965 ▲ 11605 	0.004 44.9 history1 17289 ▲ 6602	 history2
ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm	% ppm	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647	>0.05 >500 limit/base >1300 >80	 0.067 673 current 32965 11605 1016 	0.004 44.9 history1 17289 ▲ 6602 ▲ 785	 history2
ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm	% ppm	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647	>0.05 >500 limit/base >1300 >80 >20 >4	 0.067 673 current 32965 11605 1016 250 	0.004 44.9 history1 17289 ▲ 6602 ▲ 785 ▲ 166	 history2
ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	% ppm	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>0.05 >500 limit/base >1300 >80 >20 >4	 ▲ 0.067 ▲ 673 Current 32965 ▲ 11605 ▲ 1016 ▲ 250 ▲ 12 	0.004 44.9 <u>history1</u> 17289 ▲ 6602 ▲ 785 ▲ 166 ▲ 9	 history2
ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm	% ppm ESS	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>0.05 >500 limit/base >1300 >80 >20 >4 >3	 0.067 673 current 32965 11605 1016 250 12 2 	0.004 44.9 history1 17289 ▲ 6602 ▲ 785 ▲ 166 ▲ 9 1	 history2


Contact/Location: Service Manager - ACPSAN Page 1 of 2



OIL ANALYSIS REPORT







* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

Diagnosed

Tested

Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 29 May 2024

: 31 May 2024

: 31 May 2024 - Don Baldridge

Contact/Location: Service Manager - ACPSAN Page 2 of 2

T: F:

9521 MIDDLEX DR

SAN ANTONIO, TX

Contact: Service Manager

US 78217

Report Id: ACPSAN [WUSCAR] 06194624 (Generated: 05/31/2024 19:52:38) Rev: 1