




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
HAARSLEV STEAM END BLOOD DRYER
 Component
Bearing
 Fluid
USPI 1580-680 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM36315	USPM36092	USPM30042
Sample Date	Client Info	28 May 2024	09 May 2024	15 Feb 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	SEVERE	MARGINAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	3	▲ 407	0
Chromium	ppm	ASTM D5185m >20	<1	4	0
Nickel	ppm	ASTM D5185m >20	<1	2	<1
Titanium	ppm	ASTM D5185m	<1	<1	0
Silver	ppm	ASTM D5185m	1	0	0
Aluminum	ppm	ASTM D5185m >20	7	8	<1
Lead	ppm	ASTM D5185m >20	<1	0	<1
Copper	ppm	ASTM D5185m >20	<1	3	2
Tin	ppm	ASTM D5185m >20	<1	<1	1
Vanadium	ppm	ASTM D5185m	1	1	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	8	1
Barium	ppm	ASTM D5185m	0	13	0
Molybdenum	ppm	ASTM D5185m	<1	<1	0
Manganese	ppm	ASTM D5185m	<1	5	<1
Magnesium	ppm	ASTM D5185m	2	6	2
Calcium	ppm	ASTM D5185m	0	42	3
Phosphorus	ppm	ASTM D5185m 290	18	553	1355
Zinc	ppm	ASTM D5185m	2	67	2
Sulfur	ppm	ASTM D5185m	861	1339	938

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	2	8	1
Sodium	ppm	ASTM D5185m	21	18	1
Potassium	ppm	ASTM D5185m >20	5	4	1
Water	%	ASTM D6304 >2.0	1.790	▲ 6.122	▲ 2.37
ppm Water	ppm	ASTM D6304 >20000	17907	▲ 61223	▲ 23700

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	4492	▲ 299069	1306
Particles >6µm	ASTM D7647 >2500	1765	▲ 274439	453
Particles >14µm	ASTM D7647 >160	106	▲ 135010	51
Particles >21µm	ASTM D7647 >40	35	▲ 53583	17
Particles >38µm	ASTM D7647 >10	8	▲ 142	3
Particles >71µm	ASTM D7647 >3	1	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/14	19/18/14	▲ 25/25/24	18/16/13

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.6	0.86	0.94	0.59




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.0	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 641	658	452.6	668

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM36315 **Received** : 29 May 2024
Lab Number : 06194628 **Tested** : 31 May 2024
Unique Number : 11056751 **Diagnosed** : 31 May 2024 - Jonathan Hester
Test Package : IND 2

TYSON-LEXINGTON-USP - MAIN PLANT
 PO BOX 920, PROSPECT ROAD US 283
 LEXINGTON, NE
 US 68850
 Contact: SCOTT NIERMAN

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)