




OIL ANALYSIS REPORT



Machine Id
CATERPILLAR GM01 - DA LUBRICANT BLUE FLAME HB-5 SAE 40 (S/N LGS00177)
 Component
Biogas Engine
 Fluid
D-A Lubricant Blue Flame HB-5 40W (140 GAL)

Sample Rating Trend



DIAGNOSIS

- Recommendation**
No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**
An increase in the iron level is noted. All other component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0880166	WC0880165	WC0880164
Sample Date	Client Info		28 May 2024	20 May 2024	13 May 2024
Machine Age	hrs	Client Info	80412	80224	80060
Oil Age	hrs	Client Info	352	164	827
Oil Changed	Client Info		Not Chngd	Changed	Not Chngd
Sample Status			MARGINAL	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >45	▲ 43	14	15
Chromium	ppm	ASTM D5185m >2	2	1	0
Nickel	ppm	ASTM D5185m >2	1	<1	<1
Titanium	ppm	ASTM D5185m	2	2	<1
Silver	ppm	ASTM D5185m >5	0	<1	0
Aluminum	ppm	ASTM D5185m >10	3	2	2
Lead	ppm	ASTM D5185m >5	<1	<1	<1
Copper	ppm	ASTM D5185m >14	5	3	2
Tin	ppm	ASTM D5185m >13	3	2	4
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	7	5	4
Barium	ppm	ASTM D5185m	1	0	0
Molybdenum	ppm	ASTM D5185m	4	3	2
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	18	13	17
Calcium	ppm	ASTM D5185m	2608	1737	1784
Phosphorus	ppm	ASTM D5185m	489	331	323
Zinc	ppm	ASTM D5185m	577	378	387
Sulfur	ppm	ASTM D5185m	6366	4416	5072

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >200	158	75	169
Sodium	ppm	ASTM D5185m	1	0	2
Potassium	ppm	ASTM D5185m >20	2	1	1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624 >20	5.0	4.6	5.2
Sulfation	Abs/.1mm	*ASTM D7415 >30	20.8	18.8	24.4


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	11.4	10.1	13.1
Acid Number (AN)	mg KOH/g	ASTM D8045	1.29	1.07	▲ 2.622
Base Number (BN)	mg KOH/g	ASTM D2896	3.58	4.06	▲ 2.58




OIL ANALYSIS REPORT


▲ Ferrous Alloys




FT-IR (Direct Trend)




Acid Number



Base Number



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.3	13.2	13.5

GRAPHS


▲ Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0880166

Lab Number : 06194685

Unique Number : 11056808

Test Package : MOB 2

Received : 29 May 2024

Tested : 31 May 2024

Diagnosed : 31 May 2024 - Don Baldrige

ONSLow

465 MEADOWVIEW RD

JACKSONVILLE, NC

US 28540

Contact: THOMAS BURTON

thomas.burton@cubedistrictenergy.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)