


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER BSD 50T 5831166 (S/N 3841)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

ჰოე2017 May2018 Jan-2020 Dec2020 Ju2021 Mar2022 Jun-2023 May202-						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012571	KCPA010179	KCPA002112
Sample Date		Client Info		08 May 2024	12 Dec 2023	29 Jun 2023
Machine Age	hrs	Client Info		34159	51315	27973
Oil Age	hrs	Client Info		2844	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	6	12	8
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	2	0	14
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	53	4	32
Calcium	ppm	ASTM D5185m	2	<1	0	1
Phosphorus	ppm	ASTM D5185m		3	0	5
Zinc	ppm	ASTM D5185m		22	35	66
Sulfur	ppm	ASTM D5185m		23075	17145	19439
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	19	0	0
Sodium	ppm	ASTM D5185m		10	4	5
Potassium	ppm	ASTM D5185m	>20	4	0	2
Water	%	ASTM D6304	>0.05	0.020	0.006	0.016
ppm Water	ppm	ASTM D6304	>500	200	66	165.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5819	866	
Particles >6µm		ASTM D7647	>1300	<u> </u>	280	
Particles >14µm		ASTM D7647	>80	206	26	
Particles >21µm		ASTM D7647	>20	<u></u> 63	6	
Particles >38µm		ASTM D7647	>4	5	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15	17/15/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.34	0.33



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No.

Lab Number : 06195429 Unique Number : 11057552

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA012571 Received : 30 May 2024

Tested : 31 May 2024 Diagnosed : 31 May 2024 - Angela Borella

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

H&S MANUFACTURING

2913 SINGLETON ST ROWLETT, TX US 75088

Contact: SERVICE MANAGER

T: F: