


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 7072730**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

|                 |        | Ma           | r <sup>2</sup> 021 | Feb 2023 May 203 | 24          |              |
|-----------------|--------|--------------|--------------------|------------------|-------------|--------------|
| SAMPLE INFORM   | MATION | method       | limit/base         | current          | history1    | history2     |
| Sample Number   |        | Client Info  |                    | KCPA018296       | KCP46372    | KCP30806     |
| Sample Date     |        | Client Info  |                    | 16 May 2024      | 28 Feb 2023 | 26 Mar 2021  |
| Machine Age     | hrs    | Client Info  |                    | 12902            | 8092        | 2205         |
| Oil Age         | hrs    | Client Info  |                    | 3917             | 5887        | 2205         |
| Oil Changed     |        | Client Info  |                    | Changed          | Changed     | Changed      |
| Sample Status   |        |              |                    | ATTENTION        | ATTENTION   | ABNORMAL     |
| WEAR METALS     |        | method       | limit/base         | current          | history1    | history2     |
| Iron            | ppm    | ASTM D5185m  | >50                | <1               | <1          | 1            |
| Chromium        | ppm    | ASTM D5185m  | >10                | <1               | 0           | 0            |
| Nickel          | ppm    | ASTM D5185m  | >3                 | 0                | 0           | 0            |
| Titanium        | ppm    | ASTM D5185m  | >3                 | <1               | 0           | 0            |
| Silver          | ppm    | ASTM D5185m  | >2                 | 0                | 0           | <1           |
| Aluminum        | ppm    | ASTM D5185m  | >10                | 2                | <1          | <1           |
| Lead            | ppm    | ASTM D5185m  | >10                | <1               | 0           | <1           |
| Copper          | ppm    | ASTM D5185m  | >50                | 2                | 8           | 4            |
| Tin             | ppm    | ASTM D5185m  | >10                | <1               | 0           | 0            |
| Antimony        | ppm    | ASTM D5185m  |                    |                  |             | <1           |
| Vanadium        | ppm    | ASTM D5185m  |                    | 0                | 0           | 0            |
| Cadmium         | ppm    | ASTM D5185m  |                    | 0                | 0           | 0            |
| ADDITIVES       |        | method       | limit/base         | current          | history1    | history2     |
| Boron           | ppm    | ASTM D5185m  | 0                  | 0                | 0           | 9            |
| Barium          | ppm    | ASTM D5185m  | 90                 | 8                | 0           | 0            |
| Molybdenum      | ppm    | ASTM D5185m  | 0                  | <1               | 0           | 0            |
| Manganese       | ppm    | ASTM D5185m  |                    | 0                | <1          | <1           |
| Magnesium       | ppm    | ASTM D5185m  | 100                | 80               | 48          | 55           |
| Calcium         | ppm    | ASTM D5185m  | 0                  | 2                | 0           | 3            |
| Phosphorus      | ppm    | ASTM D5185m  | 0                  | 4                | <1          | 6            |
| Zinc            | ppm    | ASTM D5185m  | 0                  | 19               | 29          | 9            |
| Sulfur          | ppm    | ASTM D5185m  | 23500              | 23047            | 20428       | 13530        |
| CONTAMINANTS    |        | method       | limit/base         | current          | history1    | history2     |
| Silicon         | ppm    | ASTM D5185m  | >25                | 6                | 2           | <1           |
| Sodium          | ppm    | ASTM D5185m  |                    | 17               | 10          | 16           |
| Potassium       | ppm    | ASTM D5185m  | >20                | 8                | 6           | 11           |
| Water           | %      | ASTM D6304   | >0.05              | 0.025            | 0.019       | 0.017        |
| ppm Water       | ppm    | ASTM D6304   | >500               | 256              | 191.2       | 170.9        |
| FLUID CLEANLIN  | ESS    | method       | limit/base         | current          | history1    | history2     |
| Particles >4μm  |        | ASTM D7647   |                    | 6415             | 5436        | 14338        |
| Particles >6µm  |        | ASTM D7647   | >1300              | <u> </u>         | 1970        | <u></u> 5834 |
| Particles >14μm |        | ASTM D7647   | >80                | <b>100</b>       | 114         | <u> </u>     |
| Particles >21µm |        | ASTM D7647   | >20                | 27               | 16          | <b>△</b> 23  |
| Particles >38µm |        | ASTM D7647   | >4                 | 0                | 1           | 1            |
| Particles >71µm |        | ASTM D7647   | >3                 | 0                | 0           | 0            |
| Oil Cleanliness |        | ISO 4406 (c) | >/17/13            | <b>20/18/14</b>  | 0 20/18/14  | △ 20/14      |
| FLUID DEGRADA   | TION   | method       | limit/base         | current          | history1    | history2     |



## **OIL ANALYSIS REPORT**







Laboratory Sample No.

: KCPA018296 Lab Number : 06195435 Unique Number: 11057558

Received **Tested** 

: 30 May 2024 : 31 May 2024 Diagnosed

: 31 May 2024 - Angela Borella

Contact: Service Manager

15453 WOLF CROSSING

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - SALJUS

JUSTIN, TX

US 76247

T:

F: