


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SM 10 5954485 (S/N 2017)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	May2220 Apr2221 May2224					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018018	KCP33679	KCP24363
Sample Date		Client Info		22 May 2024	28 Apr 2021	27 May 2020
Machine Age	hrs	Client Info		17870	7581	6949
Oil Age	hrs	Client Info		0	631	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	<1	<1	<1
Copper	ppm	ASTM D5185m	>50	15	2	16
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	1
Barium	ppm	ASTM D5185m	90	<1	0	<1
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	2	52	8
Calcium	ppm	ASTM D5185m	0	0	0	1
Phosphorus	ppm	ASTM D5185m	0	7	0	5
Zinc	ppm	ASTM D5185m	0	1	32	35
Sulfur	ppm	ASTM D5185m	23500	16551	18283	15736
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	1	<1
Sodium	ppm	ASTM D5185m		0	14	3
Potassium	ppm	ASTM D5185m	>20	1	2	<1
Water	%	ASTM D6304	>0.05	0.006	0.027	0.015
ppm Water	ppm	ASTM D6304	>500	67	270.8	151.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		79950	4992	
Particles >6µm		ASTM D7647	>1300	<b>10006</b>	<u>▲</u> 1752	
Particles >14µm		ASTM D7647	>80	<b>△</b> 396	<u> </u>	
Particles >21µm		ASTM D7647	>20	<u> </u>	<u></u> 66	
Particles >38μm		ASTM D7647	>4	<u> </u>	<b>9</b>	
Particles >71µm		ASTM D7647	>3	1	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>23/21/16</u>	<u>▲</u> 18/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory

Sample No. Lab Number

: KCPA018018 : 06195437 Unique Number : 11057560

Received : 30 May 2024 **Tested** Diagnosed

: 31 May 2024

: 31 May 2024 - Angela Borella

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: ? ? - ARSCAR

2445 MCIVER LN, SUITE 102

CARROLLTON, TX

US 75006

Contact:

T: