




OIL ANALYSIS REPORT



Machine Id
MTNM01BE
 Component
Biogas Engine
 Fluid
SHELL MYSELLA S5 N 40 (160 GAL)

Sample Rating Trend



NORMAL

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0775194	WC0775226	WC0775230
Sample Date	Client Info		28 May 2024	21 May 2024	12 May 2024
Machine Age	hrs	Client Info	43106	42930	42794
Oil Age	hrs	Client Info	391	145	593
Oil Changed	Client Info		N/A	Changed	N/A
Sample Status			NORMAL	NORMAL	SEVERE

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method		NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	4	3	5
Chromium	ppm	ASTM D5185m >3	0	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >5	3	3	3
Lead	ppm	ASTM D5185m >8	0	<1	0
Copper	ppm	ASTM D5185m >5	1	<1	1
Tin	ppm	ASTM D5185m >3	4	2	4
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	4	<1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	1	1	<1
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	17	14	18
Calcium	ppm	ASTM D5185m	1795	1595	1871
Phosphorus	ppm	ASTM D5185m 300	392	332	381
Zinc	ppm	ASTM D5185m	476	430	488
Sulfur	ppm	ASTM D5185m	4065	3835	4090

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	173	90	221
Sodium	ppm	ASTM D5185m >20	1	1	<1
Potassium	ppm	ASTM D5185m >20	0	<1	0

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >16	5.1	4.2	5.4
Sulfation	Abs/.1mm	*ASTM D7415	23.2	19.5	25.1


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	15.7	12.4	17.2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.5	1.90	0.53	1.47
Base Number (BN)	mg KOH/g	ASTM D2896 4.9	3.28	4.09	3.28



OIL ANALYSIS REPORT

FT-IR (Direct Trend)




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.7	13.5

GRAPHS


Acid Number




Iron (ppm)




Lead (ppm)




Base Number




Aluminum (ppm)




Chromium (ppm)




Viscosity @ 100°C




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0775194

Lab Number : 06195618

Unique Number : 11057741

Test Package : MOB 2

Received : 30 May 2024

Tested : 31 May 2024

Diagnosed : 01 Jun 2024 - Don Baldrige

EDL NA Recips-Morgantown

Morgantown Powerstation, 950 Shiloh

Morgantown, PA

US 19543

Contact: ARON GUNN

aron.gunn@edlenergy.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)