




FUEL REPORT

Sample Rating Trend



ISO



Machine Id

CYRUSONE MAIN TANK 3

Component

Diesel Fuel

Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is a high amount of particulates present in the fuel. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0929962	WC0869458	WCDF03701
Sample Date	Client Info			28 May 2024	12 Oct 2023	03 May 2021
Machine Age	hrs	Client Info		0	0	0
Sample Status				ATTENTION	ATTENTION	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	0.839	---	0.841	0.843
Fuel Color	text	*Visual Screen	Yellow	Red	Red	Red
ASTM Color	scalar	*ASTM D1500		L4.5	L4.5	L6.0
Visc @ 40°C	cSt	ASTM D445	3.0	2.46	2.44	2.51
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	58.9	59	60

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	2	0	10
Sulfur (UVF)	ppm	ASTM D5453		7	8	9






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	169	165	157
5% Distillation Point	°C	ASTM D86		192	189	190
10% Distill Point	°C	ASTM D86	201	202	199	201
15% Distillation Point	°C	ASTM D86		209	208	210
20% Distill Point	°C	ASTM D86	216	217	217	218
30% Distill Point	°C	ASTM D86	230	232	232	233
40% Distill Point	°C	ASTM D86	243	246	247	247
50% Distill Point	°C	ASTM D86	255	259	261	262
60% Distill Point	°C	ASTM D86	267	274	275	276
70% Distill Point	°C	ASTM D86	280	288	290	291
80% Distill Point	°C	ASTM D86	295	304	307	307
85% Distillation Point	°C	ASTM D86		315	316	316
90% Distill Point	°C	ASTM D86	310	326	327	327
95% Distillation Point	°C	ASTM D86		342	344	345
Final Boiling Point	°C	ASTM D86	341	356	351	351
Distillation Residue	%	ASTM D86	3.0	---	1.4	1.4
Distillation Loss	%	ASTM D86	3.0	---	0.9	0.8

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36	36.8	36.4
Cetane Index		ASTM D4737	<40.0	47	48.2	47.4

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	0
Sodium	ppm	ASTM D5185m	<0.1	<1	0	1
Potassium	ppm	ASTM D5185m	<0.1	0	<1	<1
Water	%	ASTM D6304	<0.05	0.006	0.004	0.004
ppm Water	ppm	ASTM D6304	<500	66	48.4	41.8
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	1.6	1.9	1.3



FUEL REPORT



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0929962 **Received** : 30 May 2024
Lab Number : 06195861 **Tested** : 11 Jun 2024
Unique Number : 11057984 **Diagnosed** : 11 Jun 2024 - Doug Bogart
Test Package : DF-2 (Additional Tests: BACTERIA, Fuel, Screen)

VITAL FUEL SYSTEMS
 1076 CLASSIC RD
 APEX, NC
 US 27539
 Contact: SERVICE
 service@vitalfuelsystems.com
 T: (919)629-8180
 F: (919)303-7399

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	● 19497	● 21140	---
Particles >6µm	ASTM D7647	>640	● 8479	● 7037	---
Particles >14µm	ASTM D7647	>80	● 1184	● 575	---
Particles >21µm	ASTM D7647	>20	● 368	● 177	---
Particles >38µm	ASTM D7647	>4	● 23	● 17	---
Particles >71µm	ASTM D7647	>3	● 2	● 1	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	● 21/20/17	● 22/20/16	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	0	---	---
Yeast	CFU/ml WC-Method	>=100000	0	---	---
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	0	<1
Nickel	ppm ASTM D5185m	<0.1	0	0	<1
Lead	ppm ASTM D5185m	<0.1	0	0	0
Vanadium	ppm ASTM D5185m	<0.1	0	0	0
Iron	ppm ASTM D5185m	<0.1	0	0	1
Calcium	ppm ASTM D5185m	<0.1	<1	<1	1
Magnesium	ppm ASTM D5185m	<0.1	0	0	0
Phosphorus	ppm ASTM D5185m	<0.1	0	6	2
Zinc	ppm ASTM D5185m	<0.1	0	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

