




FUEL REPORT

Sample Rating Trend



WATER



Machine Id
SPLIT REC 90 - SPECTRUM
 Component
Tank Gasoline
 Fluid
 {not provided} (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.

▲ Contamination

There is a light concentration of water present in the gasoline. Moderate concentration of visible dirt/debris present in the gasoline. Free water present.

Fluid Condition

The gasoline is no longer serviceable due to the presence of contaminants.



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0937962	---	---
Sample Date	Client Info		23 May 2024	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed		Client Info	N/A	---	---
Sample Status			ABNORMAL	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Water	%	ASTM D6304	<0.05	▲ 0.390	---
ppm Water	ppm	ASTM D6304	<500	▲ 3902	---
% Gasoline	%	*In-House	<0.50	60.4	---
% Biodiesel	%	*In-House	<20.0	0.0	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



FUEL REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0937962

Lab Number : 06195862

Unique Number : 11057985

Test Package : DF-5 (Additional Tests: Bacteria, Color-ASTM, GC-PercFuel, ICP, KF, KV40, PrtCount, SCREENING) Do not

Received : 30 May 2024

Tested : 11 Jun 2024

Diagnosed : 11 Jun 2024 - Doug Bogart

AGRILAND FS, INC

3321 LANDING PLACE

PALM HARBOR, FL

US 34684

Do not
Contact: GREG GORKEN
ggorken@agrilandfs.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: