




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Area  
**HOWARD SHEPPARD**  
 Machine Id  
**2573 HOWARD SHEPPARD**  
 Component  
**Front Differential**  
 Fluid  
**GEAR OIL SAE 75W90 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0934649</b>	WC0797100	WC0692953
Sample Date	Client Info		<b>12 Apr 2024</b>	30 Sep 2022	05 Apr 2022
Machine Age	mls	Client Info	<b>109311</b>	30114	150
Oil Age	mls	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	<b>238</b>	244	20
Chromium	ppm	ASTM D5185m >10	<b>1</b>	2	<1
Nickel	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	2
Aluminum	ppm	ASTM D5185m >25	<b>3</b>	4	<1
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >100	<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 400	<b>7</b>	237	210
Barium	ppm	ASTM D5185m 200	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m 12	<b>&lt;1</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>4</b>	10	5
Magnesium	ppm	ASTM D5185m 12	<b>&lt;1</b>	2	1
Calcium	ppm	ASTM D5185m 150	<b>12</b>	6	3
Phosphorus	ppm	ASTM D5185m 1650	<b>539</b>	1281	1213
Zinc	ppm	ASTM D5185m 125	<b>15</b>	10	3
Sulfur	ppm	ASTM D5185m 22500	<b>23127</b>	23199	17840

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	<b>25</b>	22	8
Sodium	ppm	ASTM D5185m	<b>4</b>	3	3
Potassium	ppm	ASTM D5185m >20	<b>3</b>	1	0
Water	%	ASTM D6304 >.2	<b>0.003</b>	0.034	0.053
ppm Water	ppm	ASTM D6304 >2000	<b>37</b>	345.0	536.9






### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ <b>392031</b>	▲ 215978	---
Particles >6µm	ASTM D7647	>5000	▲ <b>248247</b>	▲ 140554	---
Particles >14µm	ASTM D7647	>640	▲ <b>3897</b>	▲ 3757	---
Particles >21µm	ASTM D7647	>160	▲ <b>200</b>	● 240	---
Particles >38µm	ASTM D7647	>40	<b>2</b>	5	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>26/25/19</b>	▲ 25/24/19	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 2.00	<b>1.15</b>	2.29	2.47


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	109	87.1	94.3
Visc @ 100°C	cSt	ASTM D445	16.0	13.1	14.0
Viscosity Index (VI)	Scale	ASTM D2270	157	150	151

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0934649 **Received** : 30 May 2024  
**Lab Number** : 06195909 **Tested** : 02 Jun 2024  
**Unique Number** : 11058032 **Diagnosed** : 02 Jun 2024 - Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: MIKE BARRY  
 mike.barry@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)