




OIL ANALYSIS REPORT



Machine Id
DZ-6
 Component
Transmission (Manual)
 Fluid
CAT TDTO TRANS-DRIVE SAE 30 (--- GAL)

Sample Rating Trend



WATER



DIAGNOSIS

▲ Recommendation

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

Appearance is hazy. There is a moderate concentration of water present in the fluid. Moderate concentration of visible dirt/debris present in the fluid.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KFS0006081	---	---
Sample Date	Client Info		21 May 2024	---	---
Machine Age	hrs	Client Info	6500	---	---
Oil Age	hrs	Client Info	6500	---	---
Oil Changed	Client Info		Not Chngd	---	---
Sample Status			ABNORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	23	---	---
Chromium	ppm	ASTM D5185m >5	0	---	---
Nickel	ppm	ASTM D5185m >5	0	---	---
Titanium	ppm	ASTM D5185m	0	---	---
Silver	ppm	ASTM D5185m >7	0	---	---
Aluminum	ppm	ASTM D5185m >25	2	---	---
Lead	ppm	ASTM D5185m >45	1	---	---
Copper	ppm	ASTM D5185m >225	23	---	---
Tin	ppm	ASTM D5185m >10	0	---	---
Vanadium	ppm	ASTM D5185m	<1	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	---	---
Barium	ppm	ASTM D5185m	<1	---	---
Molybdenum	ppm	ASTM D5185m	2	---	---
Manganese	ppm	ASTM D5185m	<1	---	---
Magnesium	ppm	ASTM D5185m	23	---	---
Calcium	ppm	ASTM D5185m 2980	2984	---	---
Phosphorus	ppm	ASTM D5185m 1100	1098	---	---
Zinc	ppm	ASTM D5185m 1270	1307	---	---
Sulfur	ppm	ASTM D5185m	10313	---	---




CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >125	30	---	---
Sodium	ppm	ASTM D5185m	3	---	---
Potassium	ppm	ASTM D5185m >20	8	---	---
Water	%	ASTM D6304 >0.1	▲ 0.716	---	---
ppm Water	ppm	ASTM D6304 >1000	▲ 7160	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.68	---	---

OIL ANALYSIS REPORT











VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	● HAZY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	0.2%	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	102	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image	no image
Bottom				no image	no image	no image

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0006081 **Received** : 30 May 2024
Lab Number : 06195998 **Tested** : 04 Jun 2024
Unique Number : 11058121 **Diagnosed** : 04 Jun 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HARNES LLC
 855 N JAMES CAMPBELL BLVD
 COLUMBIA, TN
 38401
 Contact: BILL ENYART
 bill.enyart@selectharness.com
 T: (931)797-5353
 F: