

OIL ANALYSIS REPORT

Sample Rating Trend



Cochrane

CCH01 Governor Oil (S/N 448528)

Reservoir Hydraulic System

CONOCO MULTIPURPOSE R&O OIL ISO 68 (100 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

The lead level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

8 (100 GAL)		w2013 Sep20	14 Mar2016 Nov2017	Jun2019 Sep2020 Mar2022 A	ug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06196623	WC0843417	WC0843402
Sample Date		Client Info		18 May 2024	29 Feb 2024	08 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	5	3	3
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	2	0
Lead	ppm	ASTM D5185m	>20	27	28	26
Copper	ppm	ASTM D5185m	>20	<1	<1	<1
Tin	ppm	ASTM D5185m	>20	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		<1	3	0
Phosphorus	ppm	ASTM D5185m		14	9	14
Zinc	ppm	ASTM D5185m		1	0	0
Sulfur	ppm	ASTM D5185m		384	248	367
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	△ 65468	▲ 30992	<u>\$\text{\scale}\$ 25349</u>
Particles >6µm		ASTM D7647	>640	2362	420	446
Particles >14μm		ASTM D7647	>80	23	3	2
Particles >21µm		ASTM D7647	>20	5	1	1
Particles >38μm		ASTM D7647	>4	1	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	23/18/12	<u>22/16/9</u>	<u>22/16/9</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Aoid Number (AN)	ma 1/011/a	ACTM DODAE	0.14	0.15	0.51	0.11


Acid Number (AN)


mg KOH/g ASTM D8045 0.14


0.51




OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68.2	65.7	65.2	65.8

Color	3.



historv1

current

history2

A inn		491,520 T			
		131,3207			
chromium onickel		122,880			
	1~ - A.	30,720	yele		
6 6	V~~~	€ 7,680	1		
Mar14/16	Jun3/19 Sep26/20	8 (per 1 ml)	normal		
Non-ferrous Metals		Aug12/23 Particles (per 1 ml)	11		
copper		jo 120-	1.		
**************************************		30+	/		
	Andrews and the same of the sa	8-			
Mar3/13 + Sep24/14 4 4 Mar14/16 - Nov14/17 4 4 Mar14/16 - Nov14/17 4 Mar14/17	Jun3/19 Sep26/20	Aug12/23			
Sep, Sep, Nar Nov	Sep.	O ₄ μ		4μ 21μ	38μ 7
Viscosity @ 40°C		1	6µ 14 Acid Number	τμ 21μ	38μ /
Abnormal		₹0.60 80.48			
Base		E0.36	. ^		
Abnormal	/	0.04 0.04 0.04 0.024 0.024 0.024			
~~~~		₹ 0.12 -	4		





Laboratory

Sample No. Unique Number : 11058746

Lab Number : 06196623

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC06196623

**Bottom** 

Received **Tested** 

: 03 Jun 2024 Diagnosed

: 03 Jun 2024 - Don Baldridge

: 31 May 2024

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

srb@mbesi.com T: (570)575-9252 F: (570)227-0014

GREAT FALLS, MT US 59404

**NORTHWESTERN ENERGY** 

Contact: STANLEY BOGNATZ

6700 RAINBOW DAM RD