OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
Cochrane
Machine Id
CCH01 Generator Thrust / Guide Bearing (S/N 2S57P485)
Component
Case Drain Thrust Bearing
Fluid
CONOCO MULTIPURPOSE R&O OIL ISO 68 (100 GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC06196624**	WC0843416	WC0843396
Sample Date		Client Info		**18 May 2024**	29 Feb 2024	08 Nov 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>2	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>85	**0**	0	0
Chromium	ppm	ASTM D5185m	>20	**0**	<1	0
Nickel	ppm	ASTM D5185m	>20	**0**	0	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>40	**0**	2	0
Lead	ppm	ASTM D5185m	>60	**<1**	<1	0
Copper	ppm	ASTM D5185m	>7	**0**	0	0
Tin	ppm	ASTM D5185m	>40	**0**	<1	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m		**<1**	0	0
Calcium	ppm	ASTM D5185m		**<1**	4	0
Phosphorus	ppm	ASTM D5185m		**32**	26	32
Zinc	ppm	ASTM D5185m		**7**	7	0
Sulfur	ppm	ASTM D5185m		**327**	220	302

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	**0**	0	0
Sodium	ppm	ASTM D5185m		**<1**	0	0
Potassium	ppm	ASTM D5185m	>20	**0**	<1	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	**760**	248	170
Particles >6µm		ASTM D7647	>640	**233**	44	46
Particles >14µm		ASTM D7647	>80	**31**	4	8
Particles >21µm		ASTM D7647	>20	**8**	1	5
Particles >38µm		ASTM D7647	>4	**0**	0	2
Particles >71µm		ASTM D7647	>3	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	**17/15/12**	15/13/9	15/13/10

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.14	**0.17**	0.224	0.13

OIL ANALYSIS REPORT

Particle Trend



Acid Number



Viscosity @ 40°C



Particle Trend



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>2	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68.2	**69.8**	69.6	69.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
PrtFilter			*no image*	*no image*	*no image*

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC06196624 **Received** : 31 May 2024
Lab Number : 06196624 **Tested** : 04 Jun 2024
Unique Number : 11058747 **Diagnosed** : 04 Jun 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: FilterPatch, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NORTHWESTERN ENERGY
6700 RAINBOW DAM RD
GREAT FALLS, MT
US 59404
Contact: STANLEY BOGNATZ
srb@mbesi.com
T: (570)575-9252
F: (570)227-0014