




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**CM31 [1985132]**  
 Machine Id  
**CM31EX01-1030 (S/N 2717647)**  
 Component  
**Hydraulic System**  
 Fluid  
**MOBIL DTE 25 (--- QTS)**

## DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

Appearance is hazy. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0935408</b>	WC0913988	WC0882122
Sample Date	Client Info		<b>28 May 2024</b>	05 Mar 2024	18 Dec 2023
Machine Age	days	Client Info	<b>60</b>	60	0
Oil Age	days	Client Info	<b>60</b>	60	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >20	<b>&lt;1</b>	1	0
Tin	ppm	ASTM D5185m >20	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m	<b>62</b>	52	46
Phosphorus	ppm	ASTM D5185m	<b>269</b>	238	259
Zinc	ppm	ASTM D5185m	<b>287</b>	231	282
Sulfur	ppm	ASTM D5185m	<b>1042</b>	657	632

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>5</b>	5	<1
Sodium	ppm	ASTM D5185m	<b>3</b>	5	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	<1
Water	%	ASTM D6304 >0.05	<b>▲ 0.140</b>	▲ 0.206	---
ppm Water	ppm	ASTM D6304 >500	<b>▲ 1400</b>	▲ 2066	---

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>592</b>	---	▲ 138406
Particles >6µm	ASTM D7647	>1300	<b>322</b>	---	▲ 60086
Particles >14µm	ASTM D7647	>160	<b>55</b>	---	▲ 6095
Particles >21µm	ASTM D7647	>40	<b>18</b>	---	▲ 1694
Particles >38µm	ASTM D7647	>10	<b>3</b>	---	▲ 118
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	▲ 14
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>16/16/13</b>	---	▲ 24/23/20

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.53</b>	0.47	0.461




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.2	48.4	47.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0935408 **Received** : 31 May 2024  
**Lab Number** : 06196635 **Tested** : 05 Jun 2024  
**Unique Number** : 11058758 **Diagnosed** : 05 Jun 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF )

**LEPRINO FOODS - ALLENDALE**  
 4700 RICH STREET  
 ALLENDALE, MI  
 US 49401  
 Contact: BILL FERRIER  
 BFERRIER@LEPRINOFOODS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)