




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

RP-101

Machine Id

B57006 - COOKER DISCHARGE BEARING

Component

Gearbox

Fluid

PETRO CANADA SYNDURO SHB ISO 460 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

An increase in the copper level is noted. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0894916	WC0856111	WC0850183
Sample Date	Client Info		18 May 2024	18 Nov 2023	04 Sep 2023
Machine Age	mls	Client Info	0	0	0
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	14	<1	20
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	2	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>25	0	1	<1
Lead	ppm	ASTM D5185m	>100	<1	<1	<1
Copper	ppm	ASTM D5185m	>200	105	11	56
Tin	ppm	ASTM D5185m	>25	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	2	0
Barium	ppm	ASTM D5185m	5.0	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	5.0	<1	3	0
Calcium	ppm	ASTM D5185m	5.0	<1	2	0
Phosphorus	ppm	ASTM D5185m	60	30	38	35
Zinc	ppm	ASTM D5185m	5.0	36	0	0
Sulfur	ppm	ASTM D5185m	1900	2548	3924	2560

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	<1	<1	<1
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	4	2


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 223468	---	▲ 169004
Particles >6µm	ASTM D7647	>2500	▲ 70410	---	▲ 91732
Particles >14µm	ASTM D7647	>320	▲ 7116	---	▲ 6422
Particles >21µm	ASTM D7647	>80	▲ 1323	---	▲ 936
Particles >38µm	ASTM D7647	>20	▲ 29	---	2
Particles >71µm	ASTM D7647	>4	2	---	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 25/23/20	---	▲ 25/24/20


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.3	0.55	1.06	0.48


▲ Particle Trend




▲ Particle Trend




● Non-ferrous Metals



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	HEAVY	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	452	426	373

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




● Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0894916

Lab Number : 06196639

Unique Number : 11058762

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 31 May 2024

Tested : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Don Baldrige

HORMEL FOODS - AUSTIN

1101 NORTH MAIN ST

AUSTIN, MN

US 55912

Contact: RYAN LOWE

rslowe@hormel.com

T: (507)437-5674

F: (507)437-9805

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)