

# **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

Machine Id

# KAESER SK 20 3419424 (S/N 1063)

Component Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2022	Sep2022 Jan2023	May2023 Jan2024	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128399	KC122651	KC101063
Sample Date		Client Info		07 May 2024	30 Jan 2024	16 May 2023
Machine Age	hrs	Client Info		0	30504	78183
Oil Age	hrs	Client Info		870	0	3633
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	<1	1	<1
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		<1	0	10
Calcium	ppm	ASTM D5185m		0	2	0
Phosphorus	ppm	ASTM D5185m	500	403	404	404
Zinc	ppm	ASTM D5185m		47	23	39
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		3	3	1
Potassium	ppm	ASTM D5185m	>20	<1	2	<1
Water	%	ASTM D6304	>0.05	0.00	0.002	<b>△</b> 0.058
ppm Water	ppm	ASTM D6304	>500	0	21	▲ 580
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5230		2103
Particles >6µm		ASTM D7647	>1300	<b>1633</b>		717
Particles >14µm		ASTM D7647	>80	<b>136</b>		62
Particles >21µm		ASTM D7647	>20	<b>41</b>		13
Particles >38µm		ASTM D7647	>4	0		1
Particles >71µm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/14</b>		18/17/13
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 1.5


0.17

0.23

0.15



## **OIL ANALYSIS REPORT**







Certificate 12367

Sample No. Lab Number

Laboratory : KC128399 : 06196680 Unique Number : 11058803 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 May 2024 **Tested** : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CUTLAK [WUSCAR] 06196680 (Generated: 06/03/2024 11:29:21) Rev: 1

Contact/Location: SERVICE MANAGER - CUTLAK

**CUTRALE CITRUS JUICES** 

Contact: SERVICE MANAGER

602 MCKEAN ST

LAKELAND, FL

US 33823

T:

F: