


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

3855611 (S/N 1029)

Component Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Dec2011	May2022 Sep2022	Jan2023 May2023 Jan2024	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128251	KC122650	KC101062
Sample Date		Client Info		07 May 2024	29 Jan 2024	16 May 2023
Machine Age	hrs	Client Info		41968	39588	33438
Oil Age	hrs	Client Info		4653	0	1268
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	2
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	1
Tin	ppm	ASTM D5185m	>15	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m	500	384	362	299
Zinc	ppm	ASTM D5185m		1	0	68
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		1	2	0
Potassium	ppm	ASTM D5185m	>20	0	2	1
Water	%	ASTM D6304	>0.1	0.001	0.006	0.012
ppm Water	ppm	ASTM D6304	>1000	10	65	122.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3578	892	1885
Particles >6µm		ASTM D7647	>1300	<u> </u>	309	448
Particles >14μm		ASTM D7647	>80	<u> </u>	40	36
Particles >21µm		ASTM D7647	>20	△ 63	15	8
Particles >38μm		ASTM D7647	>4	2	1	2
Particles >71μm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	17/15/12	18/16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.02	0.42	1.18





OIL ANALYSIS REPORT












SAMPLE IMAGES method limit/base Color **Bottom**







1000

600



Certificate 12367

Laboratory Sample No. Lab Number

: KC128251 : 06196681 Unique Number : 11058804 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 May 2024 **Tested** : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

Report Id: CUTLAK [WUSCAR] 06196681 (Generated: 06/03/2024 11:29:11) Rev: 1

Contact/Location: SERVICE MANAGER - CUTLAK

CUTRALE CITRUS JUICES

Contact: SERVICE MANAGER

602 MCKEAN ST

LAKELAND, FL

US 33823

F: