




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER SK 15T 4430616 (S/N 1146)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA017865	KCP28694	KCP10510
Sample Date	Client Info	22 May 2024	17 Aug 2022	19 Aug 2020
Machine Age	hrs	56749	52712	42706
Oil Age	hrs	0	4000	0
Oil Changed	Client Info	Changed	Changed	Changed
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	<1	1	<1
Chromium	ppm ASTM D5185m >10	0	0	0
Nickel	ppm ASTM D5185m >3	0	0	<1
Titanium	ppm ASTM D5185m >3	0	0	0
Silver	ppm ASTM D5185m >2	0	<1	0
Aluminum	ppm ASTM D5185m >10	<1	<1	0
Lead	ppm ASTM D5185m >10	<1	<1	0
Copper	ppm ASTM D5185m >50	<1	20	14
Tin	ppm ASTM D5185m >10	0	<1	0
Antimony	ppm ASTM D5185m	---	---	0
Vanadium	ppm ASTM D5185m	<1	0	0
Cadmium	ppm ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	0	0	0
Barium	ppm ASTM D5185m 90	35	2	0
Molybdenum	ppm ASTM D5185m 0	0	0	0
Manganese	ppm ASTM D5185m	<1	0	0
Magnesium	ppm ASTM D5185m 100	101	12	2
Calcium	ppm ASTM D5185m 0	3	0	0
Phosphorus	ppm ASTM D5185m 0	7	8	<1
Zinc	ppm ASTM D5185m 0	28	65	17
Sulfur	ppm ASTM D5185m 23500	24613	19426	18184

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	<1	<1	1
Sodium	ppm ASTM D5185m	22	2	1
Potassium	ppm ASTM D5185m >20	5	2	0
Water	% ASTM D6304 >0.05	▲ 0.218	0.006	0.011
ppm Water	ppm ASTM D6304 >500	▲ 2180	66.4	115.1




FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	---	27794	5951
Particles >6µm	ASTM D7647 >1300	---	▲ 7554	895
Particles >14µm	ASTM D7647 >80	---	▲ 582	48
Particles >21µm	ASTM D7647 >20	---	▲ 97	13
Particles >38µm	ASTM D7647 >4	---	▲ 5	0
Particles >71µm	ASTM D7647 >3	---	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	---	▲ 22/20/16	17/13

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 1.0	0.40	0.45	0.460


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	45.5	53.6	49.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA017865 **Received** : 31 May 2024
Lab Number : 06196701 **Tested** : 03 Jun 2024
Unique Number : 11058824 **Diagnosed** : 03 Jun 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

CARMAX 7121
 10201 PHILADELPHIA RD
 WHITE MARSH, MD
 US 21162
 Contact: JOE BECKER
 joe_becker@carmax.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)