

# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



KD-1 HP NOX PUMP

Component Hydraulic System

MOBIL DELVAC 1 5W40 (--- GAL)

$\neg$			
DIA	~~	NI/	

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0012875		
Sample Date		Client Info		30 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	2		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	1		
Lead	ppm	ASTM D5185m	>20	- <1		
Copper	ppm		>20	1		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m	720	<1		
Cadmium	ppm	ASTM D5185m		0		
	ррііі	AOTIVI DOTOSIII				
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	291	86		
Barium	ppm	ASTM D5185m	0.0	0		
Molybdenum	ppm	ASTM D5185m	8.0	35		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	624	725		
Calcium	ppm	ASTM D5185m	2158	841		
Phosphorus	ppm	ASTM D5185m	1132	980		
Zinc	ppm	ASTM D5185m	1300	1115		
Sulfur	ppm	ASTM D5185m	3616	3527		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>0.05	0.042		
ppm Water	ppm	ASTM D6304	>500	423		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	416		
Particles >6µm		ASTM D7647	>1300	163		
Particles >14µm		ASTM D7647	>160	32		
Particles >21µm		ASTM D7647	>40	9		
Particles >38µm		ASTM D7647	>10	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/15/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.07		



## **OIL ANALYSIS REPORT**





Certificate 12367

Laboratory Sample No.

Lab Number : 06196717 Unique Number : 11058840

: USP0012875 Test Package : IND 2

Received : 31 May 2024 **Tested** : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

ernie.just@clearwayenergy.com T: (302)678-4353 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: NRGDOV [WUSCAR] 06196717 (Generated: 06/04/2024 06:51:41) Rev: 1

Contact/Location: ERNIE JUST - NRGDOV

1280 W NORTH ST

Contact: ERNIE JUST

DOVER, DE

US 19904