


# **OIL ANALYSIS REPORT**

## Sample Rating Trend





Machine Id

KD-2 GEN
Component
Lube System
Fluid
MOBIL DTE 10 (--- GAL)

	O.				
Δ	G١	VИ		-	-
 $^{-}$	ωп	N	J	J	$\sim$

### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

w2015 Oct2016 Jam/2018 Jam/2019 May/2020 Feb.2022 Oct2022 Jul2023 May/20									
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		USP0012880	USP0007084	USP255345			
Sample Date		Client Info		30 May 2024	25 Jan 2024	09 Nov 2023			
Machine Age	mths	Client Info		0	0	0			
Oil Age	mths	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				NORMAL	NORMAL	NORMAL			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>20	0	0	0			
Chromium	ppm	ASTM D5185m	>20	0	0	0			
Nickel	ppm	ASTM D5185m	>20	0	0	0			
Titanium	ppm	ASTM D5185m		0	0	0			
Silver	ppm	ASTM D5185m		0	0	0			
Aluminum	ppm	ASTM D5185m	>20	0	0	0			
Lead	ppm	ASTM D5185m	>20	0	0	0			
Copper	ppm	ASTM D5185m	>20	<1	<1	0			
Tin	ppm	ASTM D5185m	>20	0	0	0			
Vanadium	ppm	ASTM D5185m		<1	0	0			
Cadmium	ppm	ASTM D5185m		0	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m		0	0	0			
Barium	ppm	ASTM D5185m		0	0	0			
Molybdenum	ppm	ASTM D5185m		<1	0	0			
Manganese	ppm	ASTM D5185m		0	0	0			
Magnesium	ppm	ASTM D5185m		22	<1	1			
Calcium	ppm	ASTM D5185m		216	159	179			
Phosphorus	ppm	ASTM D5185m		560	468	483			
Zinc	ppm	ASTM D5185m		730	618	657			
Sulfur	ppm	ASTM D5185m		5449	4222	4651			
CONTAMINANTS		method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>15	<1	<1	0			
Sodium	ppm	ASTM D5185m		18	17	16			
Potassium	ppm	ASTM D5185m	>20	<1	0	0			
Water	%	ASTM D6304	>0.05	0.011	0.008	0.012			
ppm Water	ppm	ASTM D6304	>500	111	82	125.0			
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647	>5000	477	1011	671			
Particles >6µm		ASTM D7647	>1300	161	256	270			
Particles >14μm		ASTM D7647	>160	15	15	35			
Particles >21µm		ASTM D7647	>40	5	3	10			
Particles >38µm		ASTM D7647	>10	0	0	1			
Particles >71µm		ASTM D7647	>3	0	0	0			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/15/11	17/15/11	17/15/12			
FLUID DEGRADA	TION	method	limit/base	current	history1	history2			
Acid Number (AN)	mg KOH/g	ASTM D8045		0.686	0.78	1.003			



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

: 06196718 Unique Number : 11058841

: USP0012880

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 May 2024

**Tested** : 03 Jun 2024 Diagnosed : 03 Jun 2024 - Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**ENERGY CENTER DOVER LLC - DCODOV** 

1280 W NORTH ST DOVER, DE US 19904

Contact: ERNIE JUST ernie.just@clearwayenergy.com

T: (302)678-4353 F:

Contact/Location: ERNIE JUST - NRGDOV