


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id

EAST COOLING TOWER FAN

Gearbox

MOBIL SHC 630 (15 GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		ay2014 Jul201	5 Sep2016 Jan2018 Ju	in2019 May2020 May2022 Apr202	3 Jan2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0012890	USP0007083	USP255353
Sample Date		Client Info		30 May 2024	25 Jan 2024	09 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<1	0	0
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm	ASTM D5185m	>15	0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		4	<1	0
Lead	ppm	ASTM D5185m	>100	<1	<1	0
Copper	ppm	ASTM D5185m		<1	0	0
Tin	ppm	ASTM D5185m	>25	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		2	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		1	2	0
Calcium	ppm	ASTM D5185m		6	1	0
Phosphorus	ppm	ASTM D5185m		74	418	408
Zinc	ppm	ASTM D5185m		2	0	0
Sulfur	ppm	ASTM D5185m		1543	163	115
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	16	16
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	2	0
Water	%	ASTM D6304	>0.2	0.001	0.003	0.003
ppm Water	ppm	ASTM D6304	>2000	5	27	38.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	8074	254	453
Particles >6µm		ASTM D7647	>5000	1677	79	169
Particles >14μm		ASTM D7647	>640	65	7	21
Particles >21µm		ASTM D7647	>160	12	2	5
Particles >38μm		ASTM D7647	>40	0	1	0
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	20/18/13	15/13/10	16/15/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.17	0.47	0.47



OIL ANALYSIS REPORT







Certificate 12367

Report Id: NRGDOV [WUSCAR] 06196722 (Generated: 06/15/2024 06:33:46) Rev: 1

Laboratory Sample No. Lab Number

: 06196722 Unique Number : 11058845 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0012890 Received : 31 May 2024

Tested : 13 Jun 2024 Diagnosed

: 13 Jun 2024 - Jonathan Hester

1280 W NORTH ST DOVER, DE

Contact: ERNIE JUST ernie.just@clearwayenergy.com T: (302)678-4353

ENERGY CENTER DOVER LLC - DCODOV

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ERNIE JUST - NRGDOV

US 19904

F: