


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id **KD-1 GAS NOX PUMP** Component **Gearbox**

MOBIL SHC 630 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Nov2023 Jan2024 May2024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0012887	USP0007091	USP249791
Sample Date		Client Info		30 May 2024	25 Jan 2024	09 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	6	7	12
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>100	<1	0	0
Copper	ppm	ASTM D5185m	>200	<1	0	0
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		4	0	0
Phosphorus	ppm	ASTM D5185m		497	402	446
Zinc	ppm	ASTM D5185m		13	0	0
Sulfur	ppm	ASTM D5185m		23	39	59
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	14	22	10
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.2	0.001	0.003	0.003
ppm Water	ppm	ASTM D6304	>2000	11	27	30.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u> 24719</u>	▲ 68227	
Particles >6µm		ASTM D7647	>1300	^ 7920	△ 5935	
Particles >14µm		ASTM D7647	>160	636	102	
Particles >21µm		ASTM D7647	>40	<u> </u>	26	
Particles >38µm		ASTM D7647	>10	<u> 11</u>	2	
Particles >71µm		ASTM D7647	>3	1	1	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>22/20/16</u>	△ 23/20/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A aid Number (ANI)	ma 1/011/-	ACTM DODAE		0.20	٥.٢٢	0.47

Acid Number (AN)

mg KOH/g ASTM D8045

0.55

0.30

0.47



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: USP0012887 : 06196727 Unique Number : 11058850

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 May 2024

Tested : 03 Jun 2024 Diagnosed

: 03 Jun 2024 - Doug Bogart

Contact: ERNIE JUST ernie.just@clearwayenergy.com T: (302)678-4353

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: Contact/Location: ERNIE JUST - NRGDOV

1280 W NORTH ST

DOVER, DE

US 19904