


OIL ANALYSIS REPORT

RAGE U46 INGERSOLL RAND 4205 - VALMONT (S/N D4956U87C) Component





Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06196792		
Sample Date		Client Info		24 May 2024		
Machine Age	hrs	Client Info		86019		
Oil Age	hrs	Client Info		4000		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	4		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		126		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		489		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.27		





OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT						
TEOID THOFENI	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	method ASTM D445	limit/base	current 47.5	history1 	history2
	cSt		limit/base			history2 history2
Visc @ 40°C	cSt	ASTM D445		47.5		

GRAPHS











Sample No. : UCH06196792 Lab Number : 06196792

Unique Number : 11058915

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Tested Diagnosed

: 31 May 2024 : 03 Jun 2024

: 03 Jun 2024 - Wes Davis

RASMUSSEN AIR & GAS ENERGY - RAGE 655 240TH STREET WATERLOO, NE US 68069

Contact: CHASE SVOBODA chase.svoboda@rage-energy.com

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCRASWAT [WUSCAR] 06196792 (Generated: 06/03/2024 14:06:11) Rev: 1

Contact/Location: CHASE SVOBODA - UCRASWAT

T: (402)614-9926