<u>Sullivan</u> Palatek

OIL ANALYSIS REPORT

Area PALASYN 45 Machine To SULLIVAN PALATEK 23BE003761 - EMPLAS Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





NORMAL


| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|---------------|-------------|------------|-------------|----------|----------|
| Sample Number | | Client Info | | UCS06196808 | | |
| Sample Date | | Client Info | | 15 May 2024 | | |
| Machine Age | hrs | Client Info | | 7023 | | |
| Oil Age | hrs | Client Info | | 7023 | | |
| Oil Changed | | Client Info | | Not Changd | | |
| Sample Status | | | | NORMAL | | |
| CONTAMINATION | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | | |
| Chromium | ppm | ASTM D5185m | >10 | <1 | | |
| Nickel | ppm | ASTM D5185m | | 0 | | |
| Titanium | ppm | ASTM D5185m | | <1 | | |
| Silver | ppm | ASTM D5185m | | 0 | | |
| Aluminum | ppm | ASTM D5185m | >25 | 2 | | |
| Lead | ppm | ASTM D5185m | >25 | <1 | | |
| Copper | ppm | ASTM D5185m | >50 | <1 | | |
| Tin | ppm | ASTM D5185m | >15 | <1 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 0.0 | 0 | | |
| Barium | ppm | ASTM D5185m | 0.0 | <1 | | |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | | |
| Manganese | ppm | ASTM D5185m | 0 | 0 | | |
| Magnesium | ppm | ASTM D5185m | 0.0 | <1 | | |
| Calcium | ppm | ASTM D5185m | 0.0 | 0 | | |
| Phosphorus | ppm | ASTM D5185m | 966 | 621 | | |
| Zinc | ppm | ASTM D5185m | 0 | 0 | | |
| Sulfur | ppm | ASTM D5185m | 1309 | 1193 | | |
| CONTAMINANTS | 5 | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 3 | | |
| Sodium | ppm | ASTM D5185m | | 0 | | |
| Potassium | ppm | ASTM D5185m | >20 | <1 | | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.172 | 0.11 | | |

Sample Rating Trend



OIL ANALYSIS REPORT

VISUAL



| | VISUAL | | method | limit/base | current | history1 | history2 |
|---|-----------------------|-------------------------|------------------------------------|--|----------------|--|----------|
| | White Metal | scalar | *Visual | NONE | NONE | | |
| | Yellow Metal | scalar | *Visual | NONE | NONE | | |
| | Precipitate | scalar | *Visual | NONE | NONE | | |
| | Silt | scalar | *Visual | NONE | NONE | | |
| | Debris | scalar | *Visual | NONE | NONE | | |
| | Sand/Dirt | scalar | *Visual | NONE | NONE | | |
| May15/24 | Appearance | scalar | *Visual | NORML | NORML | | |
| May | Odor | scalar | *Visual | NORML | NORML | | |
| | Emulsified Water | scalar | *Visual | >0.1 | NEG | | |
| | Free Water | scalar | *Visual | | NEG | | |
| | FLUID PROPER1 | LIES | method | limit/base | current | history1 | history2 |
| | Visc @ 40°C | cSt | ASTM D445 | 39.9 | 44.0 | | |
| | | | | | | | |
| | SAMPLE IMAGES | S | method | limit/base | current | history1 | history2 |
| May15/24 + | Color | | | | A. | no image | no image |
| | Bottom | | | | | no image | no image |
| | Non-ferrous Metal | ls | | 024 May15/24 May15/24 May15/24 May15/24 | | | |
| Sample No. Lab Number Unique Number Test Package | : 11058931 : IND 2 | Recei Teste Diagr | ived : 31 ed : 03 nosed : 03 | 1 May 2024 3 Jun 2024 3 Jun 2024 - W | | SSED AIR TECHNOLOGIE MCDONOUGH, G US 3025 Contact: Service Manage | |
| scuss this sample report, enotes test methods that a | contact Customer Serv | 7025 scc | ppe of accred | litation. | rule (JCGM 106 | | T F |

Report Id: UCCOMMCD [WUSCAR] 06196808 (Generated: 06/03/2024 13:54:33) Rev: 1

Contact/Location: Service Manager - UCCOMMCD