


OIL ANALYSIS REPORT

Sample Rating Trend







ULTRA COOLANT INGERSOLL RAND UP6-30-125 CBV303880

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06196817	UCH06123869	UCH06032416
Sample Date		Client Info		15 May 2024	01 Mar 2024	21 Nov 2023
Machine Age	hrs	Client Info		38300	38572	23200
Oil Age	hrs	Client Info		0	4000	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	16	10	8
Chromium	ppm	ASTM D5185m	>5	<1	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	2	0	0
Lead	ppm	ASTM D5185m	>65	<1	0	0
Copper	ppm	ASTM D5185m	>65	2	0	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	556	879	972	934
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		2	<1	1
Magnesium	ppm	ASTM D5185m		<1	0	<1
Calcium	ppm	ASTM D5185m	242	4	2	2
Phosphorus	ppm	ASTM D5185m	0	3	0	2
Zinc	ppm	ASTM D5185m	0	7	6	3
Sulfur	ppm	ASTM D5185m	306	349	481	402
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	4	<1	<1
Sodium	ppm	ASTM D5185m		41	27	18
Potassium	ppm	ASTM D5185m	>20	3	<1	2
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.2	0.22	0.274	0.13



OIL ANALYSIS REPORT





White Metal scala	ır *Visual				
		NONE	NONE	NONE	NONE
Yellow Metal scala	ır *Visual	NONE	NONE	NONE	NONE
Precipitate scala	ır *Visual	NONE	NONE	NONE	NONE
Silt scala	ır *Visual	NONE	NONE	NONE	NONE
Debris scala	ır *Visual	NONE	NONE	NONE	NONE
Sand/Dirt scala	ır *Visual	NONE	NONE	NONE	NONE
Appearance scala	ır *Visual	NORML	NORML	NORML	NORML
Odor scala	ır *Visual	NORML	NORML	NORML	NORML
Emulsified Water scala	ır *Visual	>0.1	NEG	NEG	NEG
Free Water scala	ır *Visual		NEG	NEG	NEG

FLUID PROPERTIES		method				history2
Visc @ 40°C	cSt	ASTM D445	52	52.7	52.6	52.4


SAMPLE IMAGES


Color


Bottom




GRAPHS













Certificate 12367

Laboratory Sample No.

Test Package : IND 2

Lab Number : 06196817 Unique Number : 11058940

: UCH06196817

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 May 2024 **Tested** : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Wes Davis **A-L-L EQUIPMENT INC**

204 38TH ST MOLINE, IL US 61265

Contact: KEVIN DESPOT kevind@a-l-lequipment.com

T: (815)877-7000 F: (309)762-9950

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)