




OIL ANALYSIS REPORT

Machine Id
Brent Run CAT 2 BRRM02BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

Sample Rating Trend



DIAGNOSIS

▲ Recommendation
 We recommend that you drain the oil and perform a filter service on this component if not already done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. (Customer Sample Comment: 600 hr sample)

▲ Wear
 The tin level is severe.

▲ Contamination
 Elemental level of silicon (Si) above normal.

Fluid Condition
 The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0915812	WC0915809	WC0915799
Sample Date	Client Info	29 May 2024	17 May 2024	30 Apr 2024
Machine Age	hrs	54007	53789	53369
Oil Age	hrs	600	364	806
Oil Changed	Client Info	Not Chngd	Not Chngd	Not Chngd
Sample Status		SEVERE	ABNORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >4.0	<1.0	<1.0	<1.0
Water	WC Method	NEG	NEG	NEG
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >14	3	3	2
Chromium	ppm ASTM D5185m >3	<1	<1	0
Nickel	ppm ASTM D5185m	<1	<1	0
Titanium	ppm ASTM D5185m	<1	<1	0
Silver	ppm ASTM D5185m	<1	<1	0
Aluminum	ppm ASTM D5185m >5	3	3	2
Lead	ppm ASTM D5185m >8	3	4	2
Copper	ppm ASTM D5185m >5	2	2	3
Tin	ppm ASTM D5185m >3	▲ 5	▲ 4	2
Vanadium	ppm ASTM D5185m	<1	<1	<1
Cadmium	ppm ASTM D5185m	<1	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	81	66	0
Barium	ppm ASTM D5185m	2	0	0
Molybdenum	ppm ASTM D5185m	6	4	1
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m	31	19	7
Calcium	ppm ASTM D5185m	1848	1778	1740
Phosphorus	ppm ASTM D5185m	444	371	253
Zinc	ppm ASTM D5185m	531	430	298
Sulfur	ppm ASTM D5185m	4209	3760	2426

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >180	▲ 232	158	110
Sodium	ppm ASTM D5185m >20	0	0	<1
Potassium	ppm ASTM D5185m >20	2	3	0

INFRA-RED

method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm *ASTM D7624	5.3	5.5	5.5
Sulfation	Abs/.1mm *ASTM D7415	22.7	20.3	17.8


FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414	15.4	12.8	10.3
Acid Number (AN)	mg KOH/g ASTM D8045 1.0	1.87	0.94	0.83
Base Number (BN)	mg KOH/g ASTM D2896 5.4	3.47	3.70	3.85



OIL ANALYSIS REPORT

▲ Non-ferrous Metals




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	14.3	13.8

GRAPHS


FT-IR (Direct Trend)




Acid Number




Acid Number




Base Number




Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



▲ Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0915812

Lab Number : 06196858

Unique Number : 11058981

Test Package : MOB 2

Received : 31 May 2024

Tested : 03 Jun 2024

Diagnosed : 03 Jun 2024 - Sean Felton

EDL NA Recips-Brent Run

Brent Run Power Station, 8383 Vienna Road

Montrose, MI

US 48457-9141

Contact: Rob Stewart

Rob.Stewart@energydevelopments.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)