




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

{UNASSIGNED}

Machine Id

JAX FG ISO 220 Main Storage

Component

New (Unused) Oil

Fluid

JAX FGG-AW ISO 220 (75 GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0929838	WC0840665	---
Sample Date	Client Info			29 May 2024	24 Jul 2023	---
Machine Age	hrs	Client Info		0	0	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed	Client Info			N/A	N/A	---
Sample Status				NORMAL	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>5	0	<1	---
Chromium	ppm	ASTM D5185m	>5	0	<1	---
Nickel	ppm	ASTM D5185m	>5	0	0	---
Titanium	ppm	ASTM D5185m		0	0	---
Silver	ppm	ASTM D5185m	>5	0	0	---
Aluminum	ppm	ASTM D5185m	>5	0	0	---
Lead	ppm	ASTM D5185m	>5	0	0	---
Copper	ppm	ASTM D5185m	>5	<1	0	---
Tin	ppm	ASTM D5185m	>5	<1	0	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		0	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		0	<1	---
Manganese	ppm	ASTM D5185m		<1	0	---
Magnesium	ppm	ASTM D5185m		<1	7	---
Calcium	ppm	ASTM D5185m		0	16	---
Phosphorus	ppm	ASTM D5185m		540	595	---
Zinc	ppm	ASTM D5185m		0	9	---
Sulfur	ppm	ASTM D5185m		544	602	---






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	---
Sodium	ppm	ASTM D5185m		<1	<1	---
Potassium	ppm	ASTM D5185m	>20	2	<1	---
Water	%	ASTM D6304		0.005	0.003	---
ppm Water	ppm	ASTM D6304		53	34.1	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	1351	1617	---
Particles >6µm		ASTM D7647	>1300	388	414	---
Particles >14µm		ASTM D7647	>160	37	27	---
Particles >21µm		ASTM D7647	>40	15	7	---
Particles >38µm		ASTM D7647	>10	5	2	---
Particles >71µm		ASTM D7647	>3	4	0	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/16/12	18/16/12	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.71	0.88	---




OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	NEG	---
Free Water	scalar	*Visual	NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	219.3	229.4
Visc @ 100°C	cSt	ASTM D445		24.98	25.12
Viscosity Index (VI)	Scale	ASTM D2270		143	138

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0929838 **Received** : 31 May 2024
Lab Number : 06197180 **Tested** : 17 Jun 2024
Unique Number : 11059303 **Diagnosed** : 17 Jun 2024 - Sean Felton
Test Package : IND 2 (Additional Tests: FT-IR, ICP-NewOil, KF, KV100, PrtCount, VI)

POET BIOREFINING - Groton
 40425 133RD STREET
 GROTON, SD
 US 57445-6400
 Contact: GAVIN KRUEGER
 Gavin.Krueger@POET.COM
 T: 6(05) 846-6863
 F: (605)397-2754

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)