




# OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

Fermentation

Machine Id

Lightnin FHG51CB01 Main Fermentor, Agitator

Component

Gearbox

Fluid

JAX FGG-AW ISO 220 (46 GAL)

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition.

### Wear

Gear wear is indicated.

### Contamination

There is a high amount of particulates present in the oil. Appearance is hazy.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0888635	WC0916396	WC0853617
Sample Date	Client Info		31 May 2024	01 May 2024	18 Jan 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	▲ 347	▲ 276	151
Chromium	ppm	ASTM D5185m >15	2	1	<1
Nickel	ppm	ASTM D5185m >15	0	<1	2
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	0	2
Lead	ppm	ASTM D5185m >100	0	0	1
Copper	ppm	ASTM D5185m >200	0	0	<1
Tin	ppm	ASTM D5185m >25	0	0	<1
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	1
Manganese	ppm	ASTM D5185m	3	2	2
Magnesium	ppm	ASTM D5185m	0	0	0
Calcium	ppm	ASTM D5185m	15	13	15
Phosphorus	ppm	ASTM D5185m	651	617	626
Zinc	ppm	ASTM D5185m	0	0	0
Sulfur	ppm	ASTM D5185m	848	807	733

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<1	2	2
Sodium	ppm	ASTM D5185m	<1	<1	0
Potassium	ppm	ASTM D5185m >20	0	0	1
Water	%	ASTM D6304 >0.2	0.004	0.010	0.010
ppm Water	ppm	ASTM D6304 >2000	42	107	101

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 419523	▲ 405491	▲ 196684
Particles >6µm	ASTM D7647	>5000	▲ 295302	▲ 273163	▲ 96774
Particles >14µm	ASTM D7647	>640	▲ 9780	▲ 6803	▲ 1081
Particles >21µm	ASTM D7647	>160	▲ 465	▲ 395	129
Particles >38µm	ASTM D7647	>40	4	4	2
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 26/25/20	▲ 26/25/20	▲ 25/24/17


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.57	0.67	0.68




# OIL ANALYSIS REPORT


### Particle Trend




### Water (KF)




### Ferrous Alloys



### Acid Number



### Water (KF)



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	232	231

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### Particle Count



#### Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0888635

Lab Number : 06197622

Unique Number : 11059745

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 03 Jun 2024

Tested : 04 Jun 2024

Diagnosed : 04 Jun 2024 - Don Baldrige

NOVOZYMES

P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD

FRANKLINTON, NC

US 27525

Contact: BRUCE THOMAS

brct@novozymes.com

T: (919)494-3146

F: (919)494-3456