




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**HIDE RACEWAY AC**  
 Component  
**Air Compressor**  
 Fluid  
**USPI MAX FG AIR 46 (--- GAL)**

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

Phosphorus confirmed. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USPM36397</b>	USPM30794	USPM29818
Sample Date	Client Info	<b>02 Jun 2024</b>	28 Jan 2024	24 Sep 2023
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	0
Chromium	ppm	ASTM D5185m >4	<b>0</b>	0
Nickel	ppm	ASTM D5185m >4	<b>0</b>	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0
Lead	ppm	ASTM D5185m >20	<b>0</b>	0
Copper	ppm	ASTM D5185m >40	<b>&lt;1</b>	<1
Tin	ppm	ASTM D5185m >5	<b>0</b>	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

### ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	0
Calcium	ppm	ASTM D5185m 0	<b>0</b>	0
Phosphorus	ppm	ASTM D5185m 0	<b>3</b>	6
Zinc	ppm	ASTM D5185m 0	<b>4</b>	0
Sulfur	ppm	ASTM D5185m 0	<b>9</b>	0

### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	0
Sodium	ppm	ASTM D5185m	<b>1</b>	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0
Water	%	ASTM D6304 >0.6	<b>0.013</b>	0.011
ppm Water	ppm	ASTM D6304 >6000	<b>137</b>	115

### FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 16358</b>	▲ 18555	● 5951
Particles >6µm	ASTM D7647 >1300	<b>▲ 4300</b>	▲ 3577	▲ 3242
Particles >14µm	ASTM D7647 >160	<b>● 304</b>	68	▲ 552
Particles >21µm	ASTM D7647 >40	<b>● 70</b>	12	▲ 186
Particles >38µm	ASTM D7647 >10	<b>2</b>	1	▲ 29
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	3
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 21/19/15</b>	▲ 21/19/13	▲ 20/19/16

### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.16	<b>0.10</b>	0.11




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual	>0.6	<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.8	<b>46.4</b>	46.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USPM36397  
**Lab Number** : **06197647**  
**Unique Number** : 11059770  
**Test Package** : IND 2  
**Received** : 03 Jun 2024  
**Tested** : 04 Jun 2024  
**Diagnosed** : 05 Jun 2024 - Doug Bogart

**CARGILL FORT MORGAN**  
 1505 E BURLINGTON AVE  
 FORT MORGAN, CO  
 US 80701  
 Contact: JOE ROSENFELD

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)