




OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
GARDNER DENVER 10 (S/N S618269)
 Component
Compressor
 Fluid
USPI COMP CLEAN II (--- GAL)

DIAGNOSIS

● Recommendation

Resample at the next service interval to monitor.
 NOTE: one of two samples received with same ID.

Wear

All component wear rates are normal.

● Contamination

There is a moderate amount of particulates present in the oil.

▲ Fluid Condition

The AN level is approaching the top-end of the recommended limit.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			USPM36346	USPM36680	USPM30144
Sample Date	Client Info			02 Jun 2024	11 Apr 2024	26 Feb 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				ATTENTION	SEVERE	SEVERE

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	1	1
Lead	ppm	ASTM D5185m	>25	0	1	2
Copper	ppm	ASTM D5185m	>50	3	4	2
Tin	ppm	ASTM D5185m	>15	0	1	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		2	0	0
Phosphorus	ppm	ASTM D5185m		6	23	20
Zinc	ppm	ASTM D5185m		11	13	0
Sulfur	ppm	ASTM D5185m		0	0	0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		1	<1	2
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.1	0.044	0.034	0.026
ppm Water	ppm	ASTM D6304	>1000	440	340	266


FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	12340	496	427
Particles >6µm		ASTM D7647	>2500	3965	105	106
Particles >14µm		ASTM D7647	>320	405	14	8
Particles >21µm		ASTM D7647	>80	115	4	4
Particles >38µm		ASTM D7647	>20	5	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	21/19/16	16/14/11	16/14/10

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.87	3.02	4.01




OIL ANALYSIS REPORT


● Particle Trend




↘ Water (KF)




▲ Acid Number



↘ Water (KF)



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.6	50.3	52.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



● Particle Count



▲ Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USPM36346
 Lab Number : 06197664
 Unique Number : 11059787
 Test Package : IND 2

Received : 03 Jun 2024
 Tested : 04 Jun 2024
 Diagnosed : 05 Jun 2024 - Doug Bogart

CARGILL

FORT MORGAN, CO
 US
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: