

OIL ANALYSIS REPORT

Area **S46** [283413] PNEUTECH AK100007873 - WIEGEL TOOL WORKS Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001022		
Sample Date		Client Info		03 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		322		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.24		



OIL ANALYSIS REPORT

VISUAL





White Met	tal sca	lar *Visual	NONE	NONE		
Yellow Me			NONE	NONE		
Precipitate			NONE	NONE		
Silt	sca		NONE	NONE		
Debris	sca		NONE	NONE		
Sand/Dirt	sca		NONE	NONE		
Appearan			NORML	NORML		
Odor	sca		NORML	NORML		
Emulsified			>0.1	NEG		
Free Wate	er sca			NEG		
FLUID F	PROPERTIES	metho	d limit/base	current	history1	history2
Visc @ 40				44.6		
SAMPL	E IMAGES	metho	d limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
8	rous Metals		Apr3/24			
	y @ 40°C			Acid Number		
50 Abnormal			(D)HO 0.20 (D)HO 0.20 (D) HO 0.01 (D) HO 0.21 (D) HO 0)		
45 -			Ë0.15	5-		
40 Abnormal			- a 0.10	D		
-			N 0.05	5		
35 4						P C C
Apr3/24			Apr3/24	Apr3/24		A CLEVAN
: WearCheck : UFD000102	(USA - 501 Ma	dison Ave., C e ceived	ary, NC 27513		FLUID-AII 225 SPF	RE DYNAMICS

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCFLUSCH [WUSCAR] 06197785 (Generated: 06/04/2024 13:36:21) Rev: 1

Certificate L2367

Contact/Location: ED DIENER - UCFLUSCH

F:

T: (847)678-8388