

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **PG-46** [265495] SULLAIR 003-81713 - PLOTE Component Compressor

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000314		
Sample Date		Client Info		17 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		308		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		6		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.27		



OIL ANALYSIS REPORT

VISUAL



	VISUAL		methoa	iimii/base	current	nistory i	nistory2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Apr17/24	Appearance	scalar	*Visual	NORML	NORML			
Aprl	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		47.2			
	SAMPLE IMAGES		method	limit/base	current	history1	history2	
		0	method	minubase		Thistory I	This tory 2	
April 7/24 +	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Metal	ls		Apr17/24	Acid Number			
	Abnormal			(B ^{0.30}	T			
	50 + 9			(0,030 (0,10) (0,24) (0,024) (
	(J_0) (J			는 U.18 				
	40 - Abnormal			E 0.12				
	35							
	Apr17/24			Apr17/24	Apr17/24			
	Apr			Apr	Apr			
Laboratory Sample No. Lab Number	: WearCheck USA - 50 : UFD0000314 : 06197788 : 11059911	1 Madiso Recei Teste Diagn	ved : 03 d : 04	, NC 27513 Jun 2024 Jun 2024 Jun 2024 - We	as Davis	FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, I US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.com T: (847)678-838		

Contact/Location: ED DIENER - UCFLUSCH