


OIL ANALYSIS REPORT

SMO-30 [287931] **QUINCY UTY706159 - WALDMAN LIGHTING**

Component Compressor



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001301		
Sample Date		Client Info		07 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		1		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		97		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.084		



OIL ANALYSIS REPORT









Certificate 12367

Laboratory Sample No.

Lab Number : 06197799

120

60

40 20

(40°C) 80

: UFD0001301 Unique Number : 11059922 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 03 Jun 2024 **Tested** : 05 Jun 2024

Diagnosed

: 05 Jun 2024 - Jonathan Hester

May7/24 -

Contact: ED DIENER

ed.diener@fluidairedynamics.com T: (847)678-8388

FLUID-AIRE DYNAMICS

225 SPRING LAKE DR

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Viscosity @ 40°C

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Acid Number

0.10 0.08 0.08

€0.06

은 0.04

0.00

Report Id: UCFLUSCH [WUSCAR] 06197799 (Generated: 06/05/2024 15:38:06) Rev: 1

Contact/Location: ED DIENER - UCFLUSCH

ITASCA, IL

US 60143