


## **OIL ANALYSIS REPORT**

# PG-46 [286180]

# PNEUTECH AK100006946 - WIELGUS PRODUCTS

Component



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001108		
Sample Date		Client Info		26 Apr 2024		
Machine Age	hrs	Client Info		20940		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		4		
Phosphorus	ppm	ASTM D5185m		370		
Zinc	ppm	ASTM D5185m		10		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		4		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.10		




## **OIL ANALYSIS REPORT**





VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	TES	method				history2
Visc @ 40°C	cSt	ASTM D445		49.0		
CAMBLEIMAGE	٦	ام م ملام مص	line it /le e e e		المستحداما	h: at a m . O

Color	no image	no image
Bottom	no image	no image
OD ADUG		



		Non-ferrous Metals	
	<sup>10</sup> T		
	8	copper	
mdd	Ĭ	Page   Salaranananananananananananananananananan	
	6 -	**************************************	
	41		
	2		
	-		
	0 T		÷-
		Apr26/24	Apr26/24
		1756	126
		Ap.	Α'n
		Viih. @ 400C	









Certificate 12367

Sample No. : UFD0001108 Lab Number : 06197810 Unique Number : 11059933

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 03 Jun 2024 Tested : 04 Jun 2024 Diagnosed

: 04 Jun 2024 - Wes Davis

US 60143 Contact: ED DIENER ed.diener@fluidairedynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (847)678-8388

**FLUID-AIRE DYNAMICS** 

225 SPRING LAKE DR

Report Id: UCFLUSCH [WUSCAR] 06197810 (Generated: 06/04/2024 13:36:05) Rev: 1

Contact/Location: ED DIENER - UCFLUSCH

ITASCA, IL