

OIL ANALYSIS REPORT

Sample Rating Trend



Area PG-46 [282578] PALATEK 1306060004 - MPM BOX

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORM | IATION | method | limit/base | current | history1 | history2 |
|------------------|---------------|-------------|------------|-------------|----------|----------|
| Sample Number | | Client Info | | UFD0001040 | | |
| Sample Date | | Client Info | | 29 Apr 2024 | | |
| Machine Age | hrs | Client Info | | 0 | | |
| Oil Age | hrs | Client Info | | 0 | | |
| Oil Changed | | Client Info | | Changed | | |
| Sample Status | | | | NORMAL | | |
| CONTAMINATION | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | | |
| Nickel | ppm | ASTM D5185m | | 0 | | |
| Titanium | ppm | ASTM D5185m | | 0 | | |
| Silver | ppm | ASTM D5185m | | 0 | | |
| Aluminum | ppm | ASTM D5185m | >25 | 0 | | |
| Lead | ppm | ASTM D5185m | >25 | 0 | | |
| Copper | ppm | ASTM D5185m | >50 | 0 | | |
| Tin | ppm | ASTM D5185m | >15 | 0 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | | |
| Barium | ppm | ASTM D5185m | | 0 | | |
| Molybdenum | ppm | ASTM D5185m | | 0 | | |
| Manganese | ppm | ASTM D5185m | | 0 | | |
| Magnesium | ppm | ASTM D5185m | | 0 | | |
| Calcium | ppm | ASTM D5185m | | 0 | | |
| Phosphorus | ppm | ASTM D5185m | | 298 | | |
| Zinc | ppm | ASTM D5185m | | 0 | | |
| Sulfur | ppm | ASTM D5185m | | 0 | | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 0 | | |
| Sodium | ppm | ASTM D5185m | | 2 | | |
| Potassium | ppm | ASTM D5185m | >20 | 0 | | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.067 | | |



OIL ANALYSIS REPORT

Acid Number 0.08 (B/H0.06 Acid Number (mg K 200 0.00 Apr29/24 -Apr29/24 Viscosity @ 40°C 52 Abnormal 50 48 (J-046 (J-046 44 42 40 Abnom 38 Apr29/24 Apr29/24

| | VISUAL | | method | limit/base | current | history1 | history2 | |
|---|--|---------------|--|--|-------------|--|----------|--|
| | White Metal | scalar | *Visual | NONE | NONE | | | |
| | Yellow Metal | scalar | *Visual | NONE | NONE | | | |
| | Precipitate | scalar | *Visual | NONE | NONE | | | |
| | Silt | scalar | *Visual | NONE | NONE | | | |
| | Debris | scalar | *Visual | NONE | NONE | | | |
| | Sand/Dirt | scalar | *Visual | NONE | NONE | | | |
| Apr29/24 | Appearance | scalar | *Visual | NORML | NORML | | | |
| Ap | Odor | scalar | *Visual | NORML | NORML | | | |
| | Emulsified Water | scalar | *Visual | >0.1 | NEG | | | |
| 1 | Free Water | scalar | *Visual | | NEG | | | |
| | FLUID PROPERT | IES | method | limit/base | current | history1 | history2 | |
| | Visc @ 40°C | cSt | ASTM D445 | | 46.1 | | | |
| | SAMPLE IMAGES | 6 | method | limit/base | current | history1 | history2 | |
| Apr29/24 + | Color | | | | | no image | no image | |
| | Bottom | | | | | no image | no image | |
| | Non-ferrous Metal | s | | Apr29/24 | | | | |
| | Viscosity @ 40°C | | | (g) 80.0 | Acid Number | | | |
| | 50 50 (2,00+) XS 40 35 +72/62/49 | | | 4pr/29/24 4pr/20/24 4pr/20 | Apr29/24 | | | |
| Laboratory Sample No. Lab Number Unique Number Test Package | : WearCheck USA - 50 : UFD0001040 : 06197812 : 11059935 | Rece Teste | Addison Ave., Cary, NC 27513 Received : 03 Jun 2024 Tested : 05 Jun 2024 Diagnosed : 05 Jun 2024 - Wes Davis Se at 1-800-237-1369. 2025 scope of accreditation. | | | FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.co | | |

Contact/Location: ED DIENER - UCFLUSCH