




# PROBLEM SUMMARY


Sample Rating Trend




Machine Id  
**SULLAIR 201005180005 - LOPAREX LLC**  
 Component  
**Compressor**  
 Fluid  
**PG 32 (10 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Acid Number



▲ Ferrous Alloys



## RECOMMENDATION

The oil change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	NORMAL	NORMAL
Iron	ppm ASTM D5185m >50	▲ 175	2	<1
Acid Number (AN)	mg KOH/g ASTM D8045	▲ 8.857	0.48	0.25

Customer Id: AIRGREWC  
 Sample No.: WC06197836  
 Lab Number: 06197836  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

NORMAL



**15 May 2023 Diag: Don Baldrige**

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



**19 Jan 2023 Diag: Jonathan Hester**

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



**24 Nov 2021 Diag: Don Baldrige**

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**SULLAIR 201005180005 - LOPAREX LLC**  
 Component  
**Compressor**  
 Fluid  
**PG 32 (10 GAL)**

## DIAGNOSIS

### ▲ Recommendation

The oil change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

### ▲ Wear

The iron level is severe.

### Contamination

There is no indication of any contamination in the oil.

### ▲ Fluid Condition

The AN level is well above the recommended limit. TAN level indicates possible presence of varnish. The oil is no longer serviceable.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC06197836</b>	WC0696992	WC0771121
Sample Date	Client Info		<b>29 May 2024</b>	15 May 2023	19 Jan 2023
Machine Age	hrs	Client Info	<b>54527</b>	47729	46154
Oil Age	hrs	Client Info	<b>4000</b>	1500	6828
Oil Changed	Client Info		<b>Changed</b>	Not Changd	Not Changd
Sample Status			<b>SEVERE</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>▲ 175</b>	2	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >50	<b>3</b>	2	2
Tin	ppm	ASTM D5185m >15	<b>1</b>	6	7
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>179</b>	264	268
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	2	2
Phosphorus	ppm	ASTM D5185m	<b>8</b>	5	<1
Zinc	ppm	ASTM D5185m	<b>0</b>	12	16
Sulfur	ppm	ASTM D5185m	<b>396</b>	463	559




## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>9</b>	22	22
Sodium	ppm	ASTM D5185m	<b>60</b>	98	103
Potassium	ppm	ASTM D5185m >20	<b>2</b>	4	3

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>▲ 8.857</b>	0.48	0.25


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	47.9	48.7	48.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC06197836  
**Lab Number** : 06197836  
**Unique Number** : 11059959  
**Test Package** : IND 2  
**Received** : 03 Jun 2024  
**Tested** : 05 Jun 2024  
**Diagnosed** : 05 Jun 2024 - Jonathan Hester

**FS-COMPRESSION CO, LLC**  
 203 AERO COURT  
 GREENSBORO, NC  
 US 27409  
 Contact: Dallas Burcham  
 dallas.burcham@fs-compression.com  
 T: (336)605-9622  
 F: (336)605-9844

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)