


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER BSD 50T 7918743 (S/N 1648)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May202	2 Feb 2023	Aug2023 M	ar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130446	KC125307	KCP112257
Sample Date		Client Info		19 Mar 2024	28 Aug 2023	01 Feb 2023
Machine Age	hrs	Client Info		18181	14178	9733
Oil Age	hrs	Client Info		5000	0	3000
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	1	3	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	15	5	4
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		<1	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	2	1	<1
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		2	2	3
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	3
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	1	2	<1
Water	%	ASTM D6304	>0.05	0.005	0.003	0.003
ppm Water	ppm	ASTM D6304	>500	56	29.6	32.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			997	
Particles >6μm		ASTM D7647	>1300		265	
Particles >14μm		ASTM D7647	>80		19	
Particles >21µm		ASTM D7647	>20		4	
Particles >38µm		ASTM D7647	>4		2	
Particles >71µm		ASTM D7647	>3		1	
Oil Cleanliness		ISO 4406 (c)	>/17/13		17/15/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.38


0.439


0.40



OIL ANALYSIS REPORT













GRAPHS













Certificate 12367

Laboratory Sample No.

Lab Number : 06198192 Unique Number : 11060315 Test Package : IND 2

: KC130446

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 03 Jun 2024 **Tested** : 05 Jun 2024

Diagnosed : 05 Jun 2024 - Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HUHTAMAKI PACKAGING

9201 PACKAGING DR DESOTO, KS

US 66018

Contact: TRENTON ST JOHN trenton.stjohn@huhtamaki.com

> T: F:

Report Id: HUHDES [WUSCAR] 06198192 (Generated: 06/05/2024 13:20:31) Rev: 1

Contact/Location: TRENTON ST JOHN - HUHDES