




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**PELLET MILL 2**  
 Component  
**Gearbox**  
 Fluid  
**USPI FG GEAR 220 (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USPM36406</b>	USPM30320	USPM29798
Sample Date	Client Info	<b>29 May 2024</b>	28 Feb 2024	28 Sep 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>2</b>	0	0
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>2</b>	7	13
Lead	ppm	ASTM D5185m >100	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>1</b>	<1	3
Calcium	ppm	ASTM D5185m	<b>8</b>	<1	0
Phosphorus	ppm	ASTM D5185m	<b>522</b>	537	531
Zinc	ppm	ASTM D5185m	<b>3</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>543</b>	538	518

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>3</b>	2	2
Sodium	ppm	ASTM D5185m	<b>1</b>	2	2
Potassium	ppm	ASTM D5185m >20	<b>2</b>	<1	0
Water	%	ASTM D6304 >0.2	<b>0.00</b>	0.005	0.003
ppm Water	ppm	ASTM D6304 >2000	<b>0</b>	54	29.1






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>▲ 79089</b>	---	---
Particles >6µm	ASTM D7647 >5000	<b>▲ 22669</b>	---	---
Particles >14µm	ASTM D7647 >640	<b>▲ 4243</b>	---	---
Particles >21µm	ASTM D7647 >160	<b>▲ 1233</b>	---	---
Particles >38µm	ASTM D7647 >40	<b>▲ 65</b>	---	---
Particles >71µm	ASTM D7647 >10	<b>5</b>	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>▲ 23/22/19</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.49</b>	0.49	0.44


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	<b>▲ MODER</b>
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>206</b>	206	205

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USPM36406  
**Lab Number** : 06198208  
**Unique Number** : 11060331  
**Test Package** : IND 2

**CARGILL FEED & NUTRITION - MILTON**  
 1425 E HIGH ST  
 MILTON, WI  
 US 53563  
 Contact: Sean Bertrand  
 sean\_bertrand@cargill.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)