

OIL ANALYSIS REPORT

Sample Rating Trend







RW1-MOB Component **Gearbox** {not provided} (--- QTS)

Machine Id

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0935382		
Sample Date		Client Info		03 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	4		
Chromium	ppm	ASTM D5185m	>15	<1		
Nickel	ppm	ASTM D5185m	>15	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>100	<1		
Copper	ppm	ASTM D5185m	>200	<1		
Tin	ppm	ASTM D5185m	>25	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		40		
Calcium	ppm	ASTM D5185m		4		
Phosphorus	ppm	ASTM D5185m		6		
Zinc	ppm	ASTM D5185m		2		
Sulfur	ppm	ASTM D5185m		10971		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2


0.40

Acid Number (AN)

mg KOH/g ASTM D8045




OIL ANALYSIS REPORT







GRAPHS

Bottom









no image

no image





Certificate 12367

Laboratory Sample No.

Lab Number : 06198315

Test Package : IND 2

: WC0935382 Unique Number : 11060438

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 03 Jun 2024 **Tested** Diagnosed

: 04 Jun 2024 : 05 Jun 2024 - Jonathan Hester

1170 ATLANTA INDUSTRIAL DR MARIETTA, GA US 30066

COBB CO MARIETTA WATER AUTHORITY

Contact: Bobby Fields bfields@ccmwa.org T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: