


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

## **KAESER 6588143**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

OAMBLE INFORM	ATION					
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017943	KCP37356	KCP36930
Sample Date		Client Info		23 May 2024	06 Sep 2022	06 Sep 2021
Machine Age	hrs	Client Info		35361	24353	16068
Oil Age	hrs	Client Info		4069	6000	2000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	6	6	9
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	1	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	1	0	3
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	22	83
Zinc	ppm	ASTM D5185m	0	12	0	0
Sulfur	ppm	ASTM D5185m	23500	22506	16299	13194
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	3
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	0.008	0.006	0.007
ppm Water	ppm	ASTM D6304	>500	85	64.6	72.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5293	1484	
Particles >6µm		ASTM D7647	>1300	<b>1706</b>	260	
Particles >14µm		ASTM D7647	>80	<b>234</b>	11	
Particles >21µm		ASTM D7647	>20	<u> </u>	3	
Particles >38µm		ASTM D7647	>4	<u> </u>	0	
Particles >71µm		ASTM D7647	>3	1	0	
. a						
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15	18/15/11	



### **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory

Sample No. Lab Number

: KCPA017943 : 06199129 Unique Number : 11061252

Received : 04 Jun 2024 **Tested** Diagnosed

: 05 Jun 2024 : 06 Jun 2024 - Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**GREENWASTE RECOVERY INC** 

651 CHARLES ST SAN JOSE, CA US 95112

Contact: ADOLFO ALDANA adolfo.aldana@greenwaste.com

T:

Report Id: GRESANCA [WUSCAR] 06199129 (Generated: 06/06/2024 11:24:20) Rev: 1

Contact/Location: ADOLFO ALDANA - GRESANCA

F: