


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER AIRCENTER SM 10 6009285 (S/N 2480)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep 2018	Jan 2020	Mar2021 Apr2022 I	May 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017682	KCP44565	KCP36820
Sample Date		Client Info		16 May 2024	08 Apr 2022	26 Mar 2021
Machine Age	hrs	Client Info		17006	11482	8897
Oil Age	hrs	Client Info		2732	2584	2780
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	23	14	8
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	12
Barium	ppm	ASTM D5185m	90	<1	0	2
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	3	20	32
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	0	4	11
Zinc	ppm	ASTM D5185m	0	1	62	32
Sulfur	ppm	ASTM D5185m	23500	24396	16017	15661
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	9	13
Potassium	ppm	ASTM D5185m	>20	2	2	2
Water	%	ASTM D6304	>0.05	0.004	0.008	0.012
ppm Water	ppm	ASTM D6304	>500	49	83.8	121.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2350		12118
Particles >6µm		ASTM D7647	>1300	620		<u>▲</u> 4423
Particles >14μm		ASTM D7647	>80	41		▲ 335
Particles >21µm		ASTM D7647	>20	10		<u>▲</u> 78
Particles >38μm		ASTM D7647	>4	0		3
Particles >71μm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13		△ 19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number

: KCPA017682 : 06199135 Unique Number : 11061258

Received : 04 Jun 2024 **Tested**

Diagnosed

: 05 Jun 2024 : 06 Jun 2024 - Don Baldridge 8168 BUSINESS WAY PLAIN CITY, OH

US 43064 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: