

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 4522424 (S/N 1151)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dm2020 Jan2022 Mm2024				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016048	KCP39604	KCP34453
Sample Date		Client Info		10 May 2024	05 Jan 2022	10 Dec 2020
Machine Age	hrs	Client Info		3362	2518	2369
Oil Age	hrs	Client Info		844	146	582
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	0
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m	>50	1	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	9
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	58	74	79
Calcium	ppm	ASTM D5185m	0	0	<1	<1
Phosphorus	ppm	ASTM D5185m	0	0	1	7
Zinc	ppm	ASTM D5185m	0	4	2	0
Sulfur	ppm	ASTM D5185m	23500	22398	18531	17926
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		11	14	12
Potassium	ppm	ASTM D5185m	>20	3	0	<1
Water	%	ASTM D6304	>0.05	0.018	0.019	0.021
ppm Water	ppm	ASTM D6304	>500	188	190.6	219.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2875	5107	4729
Particles >6µm		ASTM D7647	>1300	443	932	1405
Particles >14μm		ASTM D7647	>80	29	68	66
Particles >21µm		ASTM D7647	>20	10	19	12
Particles >38μm		ASTM D7647	>4	2	0	3
Particles >71μm		ASTM D7647	>3	2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/16/12	17/13	18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number : 06199149 Unique Number : 11061272

: KCPA016048

Received : 04 Jun 2024 **Tested** Diagnosed

: 05 Jun 2024

: 06 Jun 2024 - Don Baldridge

20055 75TH AVE N CORCORAN, MN US 55340

Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: LITCOR [WUSCAR] 06199149 (Generated: 06/06/2024 12:09:10) Rev: 1

Contact/Location: Service Manager - LITCOR

T:

F: