


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AC SM 7.5 5912763 (S/N 1336)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2017	Jul2018 Feb2020	Jul2021 Jun2022 Jun2023	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016445	KCPA002288	KCP41442
Sample Date		Client Info		24 May 2024	20 Jun 2023	06 Jun 2022
Machine Age	hrs	Client Info		4384	4141	3728
Oil Age	hrs	Client Info		600	0	612
Oil Changed		Client Info		Changed	N/A	Not Changd
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m	>50	2	3	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	5	9	38
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	55	76	77
Calcium	ppm	ASTM D5185m	0	0	2	1
Phosphorus	ppm	ASTM D5185m	0	0	4	6
Zinc	ppm	ASTM D5185m	0	11	5	6
Sulfur	ppm	ASTM D5185m	23500	23515	23692	18790
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		14	19	10
Potassium	ppm	ASTM D5185m	>20	4	4	2
Water	%	ASTM D6304	>0.05	0.017	△ 0.053	0.035
ppm Water	ppm	ASTM D6304	>500	174	▲ 532.5	350.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6581	6152	4267
Particles >6µm		ASTM D7647	>1300	2316	1108	866
Particles >14μm		ASTM D7647	>80	87	40	50
Particles >21µm		ASTM D7647	>20	22	5	11
Particles >38μm		ASTM D7647	>4	5	0	1
Particles >71μm		ASTM D7647	>3	2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	20/17/12	19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.35



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06199177 Unique Number : 11061300 Test Package : IND 2 (Additional Tests: KF, PrtCount)

: KCPA016445 Received

Tested Diagnosed

: 04 Jun 2024 : 05 Jun 2024

: 06 Jun 2024 - Don Baldridge

US 01027 Contact: MARK mark@mycozyhome.com

180 PLEASANT ST

EASTHAMPTON, MA

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: