OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
4 ESH
Component
Bearing
Fluid
USPI SBO 68 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USPM36460**	USPM30196	USPM31474
Sample Date		Client Info		**03 Jun 2024**	27 Feb 2024	28 Nov 2023
Machine Age	yrs	Client Info		**0**	0	0
Oil Age	yrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	**0**	3	0
Chromium	ppm	ASTM D5185m	>20	**0**	0	0
Nickel	ppm	ASTM D5185m	>20	**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>20	**0**	<1	1
Lead	ppm	ASTM D5185m	>20	**0**	0	0
Copper	ppm	ASTM D5185m	>20	**0**	<1	<1
Tin	ppm	ASTM D5185m	>20	**0**	0	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**<1**	<1	0
Magnesium	ppm	ASTM D5185m		**0**	<1	<1
Calcium	ppm	ASTM D5185m		**<1**	1	0
Phosphorus	ppm	ASTM D5185m		**22**	28	17
Zinc	ppm	ASTM D5185m		**0**	0	0
Sulfur	ppm	ASTM D5185m		**96**	153	32

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**<1**	<1	<1
Sodium	ppm	ASTM D5185m		**<1**	1	0
Potassium	ppm	ASTM D5185m	>20	**<1**	<1	<1
Water	%	ASTM D6304	>2	**0.000**	0.048	0.002
ppm Water	ppm	ASTM D6304		**0**	486	18

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	**2165**	---	260
Particles >6µm		ASTM D7647	>2500	**529**	---	86
Particles >14µm		ASTM D7647	>160	**57**	---	8
Particles >21µm		ASTM D7647	>40	**21**	---	3
Particles >38µm		ASTM D7647	>10	**5**	---	0
Particles >71µm		ASTM D7647	>3	**1**	---	0
Oil Cleanliness		ISO 4406 (c)	>20/18/14	**18/16/13**	---	15/14/10

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.084**	0.31	0.09

OIL ANALYSIS REPORT

Water (KF)



Particle Trend



Water (KF)



Viscosity @ 40°C



Particle Trend



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>2	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		**70.8**	67.1	70.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Particle Count



Non-ferrous Metals



Viscosity @ 40°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM36460
Lab Number : 06199250
Unique Number : 11061373
Test Package : IND 2

Received : 04 Jun 2024
Tested : 06 Jun 2024
Diagnosed : 09 Jun 2024 - Doug Bogart

TYSON - DAKOTA CITY SLAUGHTER

DAKOTA CITY, NE
US
Contact:
doug.bogart@wearcheck.com
T:
F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)