


OIL ANALYSIS REPORT

PALASYN 45 SULLIVAN PALATEK 23FE004225 - SISKEN STEEL

Component



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCS06199345	UCS06093709	
Sample Date		Client Info		23 May 2024	18 Feb 2024	
Machine Age	hrs	Client Info		1758	512	
Oil Age	hrs	Client Info		1758	512	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	J	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m		0	<1	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	<1	0	
Tin	ppm	ASTM D5185m	>15	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.0	0	0	
Barium	ppm	ASTM D5185m	0.0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	0	<1	0	
Magnesium	ppm	ASTM D5185m	0.0	0	<1	
Calcium	ppm	ASTM D5185m	0.0	0	1	
Phosphorus	ppm	ASTM D5185m	966	595	603	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	1309	1500	1472	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	2	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	<1	1	
ELLUD DEODADA	TION	method	limit/base	current	history1	history2
FLUID DEGRADA	IION	momod				

Sullivan


OIL ANALYSIS REPORT








GRAPHS

Bottom













Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06199345

Test Package : IND 2

: UCS06199345 Unique Number : 11061468

Received **Tested**

: 04 Jun 2024 : 05 Jun 2024

Diagnosed : 05 Jun 2024 - Wes Davis

GREENVILLE, SC US 29609 Contact: SCOTT scott@aircompressorservices.com

AIR COMPRESSOR SERVICES

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCAIRGRESC [WUSCAR] 06199345 (Generated: 06/05/2024 13:38:07) Rev: 1

Contact/Location: SCOTT - UCAIRGRESC

T: (877)592-9892

no image