


# **OIL ANALYSIS REPORT**

TEC 10K **GARDNER DENVER S351447 - BHE CRAIG STATION** Component





## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06199354	UCH05821633	
Sample Date		Client Info		24 May 2024	05 Apr 2023	
Machine Age	hrs	Client Info		28481	25355	
Oil Age	hrs	Client Info		6253	3293	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	2	0	
Tin	ppm	ASTM D5185m	>15	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		0	2	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		264	342	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		969	179	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	0	0	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.26	0.28	





## **OIL ANALYSIS REPORT**


















Certificate 12367

Laboratory Sample No.

Lab Number : 06199354 Unique Number : 11061477

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06199354

Received : 04 Jun 2024 **Tested** : 05 Jun 2024

Diagnosed : 05 Jun 2024 - Wes Davis **TOTAL EQUIPMENT COMPANY** 200 SMILEY DR

SAINT ALBANS, WV US 25177 Contact: Isabel Weimer

Isabel.weimer@totalequipment.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCTOTSAI [WUSCAR] 06199354 (Generated: 06/05/2024 13:47:18) Rev: 1

Contact/Location: Isabel Weimer - UCTOTSAI

T:

F: