

OIL ANALYSIS REPORT

Area SULLUBE [1120362] SULLAIR 202111080001 - GREAT PLAINS CE EAST

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

| SAMPLE INFORM | IATION | method | limit/base | current | history1 | history2 |
|------------------|---------------|-------------|------------|-------------|----------|----------|
| Sample Number | | Client Info | | UCH06199372 | | |
| Sample Date | | Client Info | | 10 May 2024 | | |
| Machine Age | hrs | Client Info | | 6110 | | |
| Oil Age | hrs | Client Info | | 6110 | | |
| Oil Changed | | Client Info | | Not Changd | | |
| Sample Status | | | | NORMAL | | |
| CONTAMINATION | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 14 | | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | | |
| Nickel | ppm | ASTM D5185m | | 0 | | |
| Titanium | ppm | ASTM D5185m | | 0 | | |
| Silver | ppm | ASTM D5185m | | 0 | | |
| Aluminum | ppm | ASTM D5185m | >25 | <1 | | |
| Lead | ppm | ASTM D5185m | >25 | 0 | | |
| Copper | ppm | ASTM D5185m | >50 | <1 | | |
| Tin | ppm | ASTM D5185m | >15 | 1 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | | |
| Barium | ppm | ASTM D5185m | 500 | 756 | | |
| Molybdenum | ppm | ASTM D5185m | | 0 | | |
| Manganese | ppm | ASTM D5185m | | <1 | | |
| Magnesium | ppm | ASTM D5185m | | 4 | | |
| Calcium | ppm | ASTM D5185m | | 6 | | |
| Phosphorus | ppm | ASTM D5185m | | 2 | | |
| Zinc | ppm | ASTM D5185m | | <1 | | |
| Sulfur | ppm | ASTM D5185m | 150 | 356 | | |
| CONTAMINANTS | 5 | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 2 | | |
| Sodium | ppm | ASTM D5185m | | 23 | | |
| Potassium | ppm | ASTM D5185m | >20 | 6 | | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.5 | 0.36 | | |



OIL ANALYSIS REPORT

VISUAL



| | VISUAL | | method | | | history1 | history2 |
|--------|--|--------------------------------------|---------------------------|---|------------------|----------|---|
| | White Metal | scalar | *Visual | NONE | NONE | | |
| | Yellow Metal | scalar | *Visual | NONE | NONE | | |
| | Precipitate | scalar | *Visual | NONE | NONE | | |
| | Silt | scalar | *Visual | NONE | NONE | | |
| | Debris | scalar | *Visual | NONE | NONE | | |
| | Sand/Dirt | scalar | *Visual | NONE | NONE | | |
| | | scalar | *Visual | NORML | NORML | | |
| | Appearance Odor | scalar | *Visual | NORML | NORML | | |
| | Emulsified Water | scalar | *Visual | >0.1 | NEG | | |
| | Free Water | scalar | *Visual | , 011 | NEG | | |
| | | | | | | | |
| | FLUID PROPER | RTIES | method | limit/base | current | history1 | history2 |
| | Visc @ 40°C | cSt | ASTM D445 | 36 | 39.6 | | |
| | SAMPLE IMAGI | ES | method | limit/base | current | history1 | history2 |
| | ⁴⁷⁰⁰ L/ ^{6W} | | | | | no image | no image |
| | Bottom | | | | | no image | no image |
| | Non-ferrous Met | | | May10/24 | Acid Number | | |
| | Viscosity @ 40°C | | | | | | |
| | 50 | | | (B)H(0.6 | Base | | |
| | 50 45 Abnormal | | | (В/НО) 0.4 Вш 0 3 | Base | | |
| | 45 45 (2) (2) (2) (4) | | | (B) 0.6 HO 0.4 L L L L L L L L L L L L L L L L L L L | 0 8 6 4 | | |
| | 50 45 (5) (5) (5) (4) (5) (5) (4) (5) (5) (5) (5) (5) (5) (5) (5) (5) (5 | | | (6),0.6 HO 0.4 Bu 0.3 Ho 0.2 U 0.1 | Base | | |
| | Abnormal Abnormal Abnormal Base Abnormal 30 | | | (0,0) | | | |
| | Abnormal Abnormal Abnormal Base Abnormal 30 | | | | | | P C C C |
| Unique | atory : WearCheck USA - 5 | 01 Madiso Recei Teste Diagn | ved : 04 d : 05 | May10/24 | Mar/10/24 | | QUIPMENT INC E BOSTON S' WICHITA, KS US 6721 KAYLA STOU |

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ðŪ

Contact/Location: MIKAYLA STOUT - UCAIRWIC

F: