




OIL ANALYSIS REPORT



Machine Id
Brent Run CAT 4 BRRM04BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

Sample Rating Trend



DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. (Customer Sample Comment: After turbo replacement)

▲ Wear

The tin level is severe. All other component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0915815	WC0915813	WC0915801
Sample Date	Client Info	03 Jun 2024	29 May 2024	30 Apr 2024
Machine Age	hrs	108105	108700	108105
Oil Age	hrs	643	489	685
Oil Changed	Client Info	Not Chngd	Not Chngd	Not Chngd
Sample Status		SEVERE	SEVERE	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >4.0	<1.0	<1.0	<1.0
Water	WC Method	NEG	NEG	NEG
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >14	3	5	3
Chromium	ppm ASTM D5185m >3	0	<1	0
Nickel	ppm ASTM D5185m	0	<1	0
Titanium	ppm ASTM D5185m	0	<1	0
Silver	ppm ASTM D5185m	0	<1	0
Aluminum	ppm ASTM D5185m >5	2	3	2
Lead	ppm ASTM D5185m >8	<1	<1	0
Copper	ppm ASTM D5185m >5	2	2	2
Tin	ppm ASTM D5185m >3	▲ 5	▲ 5	3
Vanadium	ppm ASTM D5185m	0	<1	<1
Cadmium	ppm ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	85	80	<1
Barium	ppm ASTM D5185m	<1	2	0
Molybdenum	ppm ASTM D5185m	4	5	1
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m	39	29	7
Calcium	ppm ASTM D5185m	1807	1870	1827
Phosphorus	ppm ASTM D5185m	402	438	272
Zinc	ppm ASTM D5185m	489	544	316
Sulfur	ppm ASTM D5185m	4350	4296	2843

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >180	▲ 218	▲ 231	163
Sodium	ppm ASTM D5185m >20	2	0	2
Potassium	ppm ASTM D5185m >20	2	2	0

INFRA-RED

method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm *ASTM D7624	6.1	5.1	6.1
Sulfation	Abs/.1mm *ASTM D7415	24.5	22.4	20.4


FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414	18.0	16.0	13.6
Acid Number (AN)	mg KOH/g ASTM D8045 1.0	1.81	1.86	1.17
Base Number (BN)	mg KOH/g ASTM D2896 5.4	3.2	4.86	3.61




OIL ANALYSIS REPORT

▲ Non-ferrous Metals



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FT-IR (Direct Trend)




FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.4	14.3	14.4	13.7

GRAPHS


Acid Number




Iron (ppm)




Lead (ppm)




Acid Number




Aluminum (ppm)




Chromium (ppm)




Base Number




Copper (ppm)




▲ Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0915815
Lab Number : 06199815
Unique Number : 11061938
Test Package : MOB 2

Received : 05 Jun 2024
Tested : 12 Jun 2024
Diagnosed : 12 Jun 2024 - Doug Bogart

EDL NA Recips-Brent Run
 Brent Run Power Station, 8383 Vienna Road
 Montrose, MI
 US 48457-9141
 Contact: Rob Stewart
 Rob.Stewart@energydevelopments.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: